



GUIDELINES FOR

CANADIAN DRINKING WATER QUALITY

MALATHION

Guideline Technical Document



Health
Canada

Santé
Canada

Canada 

Health Canada is the federal department responsible for helping the people of Canada maintain and improve their health. Health Canada is committed to improving the lives of all of Canada's people and to making this country's population among the healthiest in the world as measured by longevity, lifestyle and effective use of the public health care system.

Également disponible en français sous le titre :

Recommandations pour la qualité de l'eau potable au Canada: Document technique – Malathion

To obtain additional information, please contact:

Health Canada

Address Locator 0900C2

Ottawa, ON K1A 0K9

Tel.: 613-957-2991

Toll free: 1-866-225-0709

Fax: 613-941-5366

TTY: 1-800-465-7735

E-mail: publications-publications@hc-sc.gc.ca

© His Majesty the King in Right of Canada, as represented by the Minister of Health, 2023

Publication date: January 2023

This publication may be reproduced for personal or internal use only without permission provided the source is fully acknowledged.

Cat.: H144-13/26-2022E-PDF

ISBN: 978-0-660-46023-9

Pub.: 220517



GUIDELINE VALUE: The maximum acceptable concentration (MAC) for malathion in drinking water is 0.29 mg/L (290 µg/L).

EXECUTIVE SUMMARY

This guideline technical document was prepared in collaboration with the Federal-Provincial-Territorial Committee on Drinking Water and is based on assessments of malathion completed by Health Canada's Pest Management Regulatory Agency and supporting documents.

Exposure

Malathion is a registered insecticide and acaricide used on a wide variety of sites including agricultural and non-agricultural sites. In 2018 (the most recent year for which data are available), over 25 000 kg of malathion was sold in Canada (Health Canada, 2020a). Malathion may be released into surface water or soil as runoff from the application site.

Malathion is not usually found in drinking water sources in Canada. Low levels of malathion have been found in several Canadian provinces. The maximum reported concentrations are well below the MAC. Malathion is rarely detected in foods.

Health effects

Animal studies indicate that the kidney is the most sensitive target organ for malathion toxicity. There are no human studies on the effects of malathion on the kidney. The MAC of 0.29 mg/L (290 µg/L) is based on an increase in severity of chronic kidney effects seen in a two-year rat study.

Analytical and treatment considerations

The establishment of drinking water guidelines takes into consideration the ability to both measure the contaminant and remove it from drinking water supplies. Several analytical methods are available for measuring malathion in water at concentrations well below the MAC.

At the municipal level, treatment technologies are available to effectively decrease malathion concentrations in drinking water supplies. Activated carbon, membrane filtration, oxidation, and advanced oxidation processes can all be used in the treatment of malathion in drinking water. Advanced oxidation processes achieve the highest removal, with lower removals achieved through oxidation. When using degradation processes like oxidation or advanced oxidation processes, water utilities should be aware of the potential for the formation of degradation by-products (e.g., malaaxon). Pilot- and/or bench-scale testing are recommended prior to full-scale implementation.

In cases where malathion removal is desired at a small-system or household level, for example when the drinking water supply is from a private well, a residential drinking water treatment unit may be an option. Although there are no treatment units currently certified for the removal of malathion from drinking water, activated carbon adsorption and reverse osmosis technologies are expected to be effective. When using a residential drinking water treatment unit, it is important to take samples of water entering and leaving the treatment unit and send them to an accredited laboratory for analysis to ensure that adequate malathion removal is occurring.

Application of the guidelines

Note: Specific guidance related to the implementation of drinking water guidelines should be obtained from the appropriate drinking water authority.

The guideline value for malathion is protective against health effects from exposure to malathion in drinking water over a lifetime. Any exceedance of the MAC should be investigated and followed by the appropriate corrective actions, if required. For exceedances in source water where there is no treatment in place, additional monitoring to confirm the exceedance should be conducted. If it is confirmed that source water malathion concentrations are above the MAC, then an investigation to determine the most appropriate way to reduce exposure to malathion should be conducted. This may include the use of an alternate water supply or the installation of treatment. Where treatment is already in place and an exceedance occurs, an investigation should be conducted to verify the treatment and determine if adjustments are needed to lower the treated water concentration below the MAC.



TABLE OF CONTENTS

1.0 EXPOSURE CONSIDERATIONS	01
1.1 Sources and uses	01
1.2 Substance identity	02
1.3 Exposure	03
2.0 HEALTH CONSIDERATIONS	08
2.1 Kinetics	09
2.2 Health effects	10
2.3 Effects in humans	10
2.4 Effects in animals	14
2.5 Genotoxicity and carcinogenicity	18
2.6 Mode of action	20
2.7 Selected key study	21
3.0 DERIVATION OF THE HEALTH-BASED VALUE	23
4.0 ANALYTICAL AND TREATMENT CONSIDERATIONS	24
4.1 Analytical methods to detect malathion	24
4.2 Treatment considerations	26
4.2.1 Municipal-scale	26
4.2.1.1 Conventional treatment	27
4.2.1.2 Activated carbon adsorption	28
4.2.1.3 Membrane filtration	29
4.2.1.4 Oxidation and hydrolysis	32
4.2.1.5 Advanced Oxidation Processes	35
4.2.1.6 Combined technologies	37
4.2.2 Residential-scale	37
5.0 MANAGEMENT STRATEGIES	39
5.1 Monitoring	39
6.0 INTERNATIONAL CONSIDERATIONS	40
7.0 RATIONALE	42
8.0 REFERENCES	43
APPENDIX A: LIST OF ABBREVIATIONS	56
APPENDIX B: CANADIAN WATER QUALITY DATA	58





1.0 EXPOSURE CONSIDERATIONS

1.1 Sources and uses

Malathion or diethyl[(dimethoxyphosphinothioyl)thio]butanedioate is a non-systemic, broad-spectrum organophosphate insecticide and acaricide used to control a broad range of insect and arachnid pests. It acts by inhibiting the acetylcholinesterase (AChE) enzyme, thereby disrupting nervous system function. In Canada, malathion is used on a wide variety of settings including agricultural and non-agricultural sites such as human habitats, recreational areas, and outdoor ornamentals (Health Canada, 2012). In 2018 (the most recent year for which data are available), over 25 000 kg of malathion was sold in Canada (Health Canada, 2020a).

Malathion may be released into surface water or soils as runoff from the application site (ATSDR, 2003; U.S. EPA, 2009; Health Canada, 2012). In natural waters, soil and sediment, breakdown of malathion occurs primarily through microbial degradation and hydrolysis (Laveglia and Dahm, 1977; ATSDR, 2003; Health Canada, 2010; Singh et al., 2014). Malathion hydrolyses readily under neutral to alkaline conditions but is increasingly stable under acidic conditions and at low temperatures. The major transformation products (as identified in biotransformation studies) are malathion's monocarboxylic acid (MCA), dicarboxylic acid (DCA), demethyl monocarboxylic acid and demethyl dicarboxylic acid, which are not expected to persist in the environment (Health Canada, 2010). Photolysis is not a significant breakdown pathway for malathion in water or soil, with reported half-lives ranging from 0.67 to 42 days in natural and distilled waters and 173 days in sandy loam soil (ATSDR, 2003; EFSA, 2009; U.S. EPA, 2009; Health Canada, 2010). However, in some natural waters containing photosensitizing agents, photolysis may contribute to the dissipation of malathion from the water layer in the photic zone (i.e., upper layer penetrated by sunlight) (Health Canada, 2010).

In aquatic environments, malathion is non-persistent to slightly persistent under aerobic conditions (half-life of 0.3–19 days) and non-persistent in anaerobic systems (half-life of 2.5 days reported in flooded soil), with dissipation generally being fastest in alkaline systems, conditions that have been shown to favour hydrolysis (Health Canada, 2010).

As malathion is highly soluble in water (see Table 1) and does not adsorb strongly to soils, it is mobile in most soil types and its use may result in the contamination of groundwater, particularly in areas where soils are permeable (e.g., sandy soil) and/or the depth to the water table is shallow (Gervais et al., 2009; Health Canada, 2012). However, malathion is

unlikely to leach into groundwater, as it is rapidly degraded in soil by microbially mediated metabolism (half-life of 0.2–2 days) and hydrolysis under neutral to alkaline conditions (half-lives of 6.2, 1.5 and 0.5 days at pH 7, 8 and 9, respectively) (ATSDR, 2003; Health Canada, 2010). The degradation of malathion in soil is enhanced by increased moisture, pH levels, microbial activity, nitrogen content and carbon content (Laveglia and Dahm, 1977; ATSDR, 2003; EFSA, 2009; U.S. EPA, 2009; Health Canada, 2010; Kumar et al., 2019).

Based on its physical properties (vapour pressure and Henry's law constant), malathion is unlikely to volatilize appreciably from moist soils or water surfaces, or undergo long-range atmospheric transport (Health Canada, 2010). If present in air, malathion can be released to surface water or soils by rain or fog water, or be photo-oxidized (ATSDR, 2003; WHO, 2004).

Malaoxon, the oxidation transformation product that is responsible for some of the toxic effects of malathion, may form under certain environmental conditions but is expected to be non-persistent under aerobic soil conditions (half-lives of 6.5 days at pH 6.2 and 3.5 days at pH 8.2) (Gervais et al., 2009; Health Canada, 2010). Two monitoring studies investigating malaoxon formation in water, sand and soils reported a maximum of 10% malathion to malaoxon conversion (Health Canada, 2012). As with malathion, malaoxon is rapidly detoxified via hydrolysis under neutral to alkaline conditions, unlikely to leach into groundwater and more persistent under acidic conditions than alkaline conditions (half-lives of 32.5, 8.8 and 0.18 days at pH 5, 7 and 9, respectively) (ATSDR, 2003; Health Canada, 2010). Malaoxon may also be formed as a result of oxidation or advanced oxidation processes during the treatment of drinking water for the removal of pesticides (see Section 4.2).

1.2 Substance identity

Malathion ($C_{10}H_{19}O_6PS_2$) is a colourless to amber liquid belonging to the organophosphate class of chemicals (U.S. EPA, 2009; Health Canada, 2010). Formulations of malathion can contain a number of impurities at very low levels, notably malaoxon and isomalathion. In the past, manufacturing processes and improper product storage led to the presence of isomalathion, a toxic metabolite that potentiates the toxicity of malathion; however, regulatory standards have since been put in place to limit its presence and formation (Buratti and Testai, 2005; U.S. EPA, 2009; Jensen and Whatling, 2010; Health Canada, 2010, 2012).

**TABLE 1:** Properties of malathion relevant to its presence in drinking water

Property	Malathion	Interpretation
CAS Registry Number	121-75-5	Not applicable
Molecular weight (g/mol)	330.4	Not applicable
Water solubility (mg/L)	145	Highly soluble in water
Vapour pressure (volatility) (mm Hg)	3.97 x 10 ⁻⁵ at 30°C ^a 1.78 x 10 ⁻⁴ at 25°C ^a 1.2 x 10 ⁻⁴ to 8 x 10 ⁻⁶ at 20°C ^a	Can have a wide range of volatility, but generally slight to low volatility and unlikely to contaminate air ^a
Henry's Law constant (atm m ³ /mol)	1.2 x 10 ⁻⁷	Low volatilization potential
octanol:water partition coefficient (Log Kow)	2.75–2.94	Not likely to bioaccumulate

Unless otherwise indicated, information is from Health Canada, 2010.

^a Gervais et al., 2009; Health Canada, 2019a.

1.3 Exposure

The general Canadian population can be exposed to malathion primarily through food and drinking water (Health Canada, 2010, 2012). Based on dietary risk estimates using conservative assumptions and combining exposure estimates for both malathion and malaoxon (Table 2), Health Canada's Pest Management Regulatory Agency (PMRA) did not consider exposure to malathion and malaoxon from both food and drinking water to be of concern for Canadians (Health Canada, 2010). In its exposure assessment based on surveillance data, PMRA combined both malathion and malaoxon residues by converting the malaoxon residues (by multiplying them by a toxicity adjustment factor [TAF] of 24) into malathion equivalents. The use of a TAF accounts for the greater potency of malaoxon compared to malathion in regard to cholinesterase (ChE) inhibition and represents a very conservative estimate of exposure to malathion and malaoxon (see Section 3.0 for more information) (Health Canada, 2010).

TABLE 2: Chronic dietary exposure and risk for malathion and malaoxon (Health Canada, 2010)

Population Group (in years)	Chronic dietary exposure ^a	
	µg/kg bw/d	% ADI ^b
General Population	9.5	32
All Infants (< 1)	7.6	25
Children 1–2	19.7	66
Children 3–5	19	64
Children 6–12	13.1	44
Youth 13–19	9.5	32
Adults 20–49	8.5	28
Females 13–49	7.3	24
Adults 50+	6.9	23

ADI: acceptable daily intake.

^a Exposure is based on surveillance data from the Canadian Food Inspection Agency's National Chemical Residue Monitoring Program (2002–2007) and the United States Department of Agriculture Pesticide Data Program (2004–2005) and accounts for both malathion and malaoxon residues from food and drinking water. When malaoxon residues were reported to be below the limit of detection (LOD), the residue was assumed to be half-LOD. A toxicological adjustment factor of 24x was applied to malaoxon residue estimates to convert them into malathion equivalents (Health Canada, 2010).

^b ADI = 0.03 mg/kg bw per day for general population.

Water monitoring data on malathion were available from the provinces and territories (municipal and non-municipal supplies), PMRA and Environment and Climate Change Canada (Environment Canada, 2011) (Appendix B).

The exposure data provided reflect different method detection limits (MDL) of accredited laboratories used within and amongst the jurisdictions, as well as their respective monitoring programs. The data provided by the provinces and territories do not indicate the timing of monitoring in relation to pesticide application and runoff events. As a result, the exposure data and statistical analysis provide only a limited picture. Data provided by the provinces and territories indicate that malathion levels are below the method reporting limit (MRL) or MDL in most samples collected from a variety of water supplies in Canada, including surface water and groundwater, as well as treated and distributed water (British Columbia Ministry of Health, 2019; Indigenous Services Canada, 2019; Manitoba Sustainable Development, 2019; Ministère de l'Environnement et de la Lutte contre les changements climatiques, 2019; Nova Scotia Environment, 2019; Saskatchewan Water Security Agency, 2019; Ontario Ministry of the Environment, Conservation and Parks, 2020). Table 3 summarizes the monitoring data for all jurisdictions. The maximum concentration reported was 5 µg/L for treated surface water in Ontario, which is well below the proposed MAC. There were no monitoring data available in New Brunswick, Newfoundland and



Labrador, Prince Edward Island or Yukon (New Brunswick Department of Environment and Local Government, 2019; Newfoundland and Labrador Department of Municipal Affairs and Environment, 2019; PEI Department of Communities, Land and Environment, 2019; Yukon Environmental Health Services, 2019).

TABLE 3: Summary of monitoring data for malathion

Jurisdiction (MDL µg/L)	Monitoring Period	Municipal/ Non-municipal	Water Type (Municipal: ground/surface – raw, treated, distributed)	# Detects/ samples	Maximum Conc. (µg/L)
British Columbia (2)	2013–2018	Municipal	Surface – raw	0/18	–
			Ground – raw	0/13	–
FNIHB Ontario Region (0.1–5)	2014–2018	Public Water Systems	Ground – treated	0/190	–
			Ground – distribution	0/16	–
			Surface – raw	0/33	–
			Surface – treated	0/308	–
			Surface – distribution	0/23	–
			Ground – raw	0/3	–
		Semi-Public Water Systems	Ground – treated	0/16	–
			Ground – distribution	0/68	–
			Surface – raw	0/1	–
			Surface – treated	0/9	–
			Surface – distribution	0/2	–
			Private Water Systems	Ground – treated	0/3
		Ground – distribution		0/50	–
		Surface – treated		0/5	–
		FNIHB Atlantic Region (4–5)	2014–2018	Public Water Systems	Ground – treated
Ground – distribution	0/4				–
Surface – treated	0/1				–
FNIHB Quebec (0.01)	2014–2018	Drinking water system	Not given	0/4	–
Manitoba (0.1–10)	2012–2018	Ambient	Surface – ambient	0/431	–

Jurisdiction (MDL µg/L)	Monitoring Period	Municipal/ Non-municipal	Water Type (Municipal: ground/surface – raw, treated, distributed)	# Detects/ samples	Maximum Conc. (µg/L)
Nova Scotia (1–10)	2007–2018	Municipal	Ground – raw	0/72	–
			Ground – treated	0/35	–
			Surface – raw	0/35	–
			Surface – treated	0/40	–
			Distributed	0/1	–
Ontario (0.0001–9)	2011–2020	Municipal	Ground – treated	2/3955	0.1
			Surface – treated	2/3796	5
			Distribution	0/60	–
Quebec (0.1–15)	2013–2018	Municipal	Ground – distribution	0/290	–
			Surface – distribution	0/1032	–
		Municipal (Special Projects) Potatoes project ^a [2017–2018]	Ground – raw	0/46	–
			Ground – treated	0/17	–
			Ground – distribution	0/5	–
		Small systems ^b [2012–2018]	Ground – raw (municipal)	0/82	–
Ground – raw (non-municipal)	0/132		–		
Saskatchewan (0.1–10)	2014–2017	Municipal	Ground – raw	0/84	–
			Surface/Ground – distribution	0/32	–
			Surface/Ground – treated	0/4	–

FNIHB: First Nations and Inuit Health Branch; MDL: method detection limit.

^a Potato Project 2017–2018: During the period covered, analysis results of malathion pesticide found in raw, treated or distributed ground water were obtained by the Ministère de l'Environnement et de la Lutte contre les changements climatiques (2019) from 9 drinking water supplies.

^b Small Systems Project 2012–2018: During the period covered, analysis results of malathion found in raw ground water were obtained by the Ministère de l'Environnement et de la Lutte contre les changements climatiques (2019) from 25 drinking water supplies.

As part of its assessment, PMRA (Health Canada, 2010) summarized Canadian water monitoring data on malathion up to 2005. Malathion was detected in 10 samples (n = 4 274) from Canadian municipal drinking water sources with a maximum concentration of 0.08 µg/L recorded in Quebec (1991–1993), and in > 79 samples (n = > 6 716) from Canadian ambient water that may serve as a drinking water source with a maximum concentration of 1.54 µg/L recorded in Ontario (2003). The maximum malathion concentration in water sources unlikely to be used for drinking water was 2.1 µg/L (11 samples with detections; n = 150).



Canadian water monitoring data were available from the published literature and indicated that malathion is not frequently detected in drinking water sources. Sampling in corn and soybean crop sectors in Quebec from 2015 to 2017 indicated an average malathion detection frequency of 2% and a maximum malathion concentration of 5.5 µg/L in the Chibouet, Saint-Régis, des Hurons and Saint-Zéphirin Rivers (Limit of detection (LOD) = 0.02 µg/L) (Giroux, 2019). The maximum detection frequency and maximum malathion concentration for four streams from orchard and vegetable crop zones in Quebec were 33.3% and 2.7 µg/L, respectively, for the 2013–2014 period (LOD = 0.02 µg/L) (Giroux, 2017). No malathion was detected in Quebec from sampling performed in individual wells in proximity to corn, soybean, vine, orchard, vegetable and small fruit crop sectors (LOD = 0.02 µg/L) (Giroux, 2016, 2019).

In British Columbia, malathion was not detected in a study (2003–2005) of surface water and groundwater from the Lower Fraser Valley region (Reporting limit = 2.22 ng/L, n = 40 samples) (Woudneh et al., 2009a, 2009b).

Thirty-four wells from the Nova Scotia Groundwater Observation Well Network were tested for pesticides between 2004 and 2011; malathion (LOD = 0.5–5 µg/L) and malaoxon (LOD = 1 µg/L) were not detected (Nova Scotia Environment, 2015).

Other Canadian water exposure data were not available for malaoxon. Owing to the extensive monitoring programs that exist in the United States (US) along with comparable runoff events, local use patterns, site-specific hydrogeology as well as testing and reporting methods, US monitoring data were considered relevant to the Canadian context. US temperatures are generally warmer (leading to quicker degradation of malathion) with longer growing seasons and more pesticide applications. Additionally, annual usage data (up to 13 million pounds in 2000 and ~15 million pounds in 2009) indicate malathion is used in the US at much higher quantities than in Canada (up to 100 000 kg [~200 000 pounds]) (U.S. EPA, 1999; Health Canada, 2010, 2020a). The use of American monitoring data would therefore generate a conservative estimate of Canadian exposure.

In its assessment, PMRA (Health Canada, 2010) summarized US water monitoring data for malaoxon. Out of 6 297 samples collected between 1999 and 2000 from surface water and groundwater sources, malaoxon was only detected in 7 samples; its maximum concentration was 0.18 µg/L (LOD = 0.005–0.15 µg/L). In 11 samples (n = 538) of raw and finished water (collected up to 2008), the maximum concentration was 0.556 µg/L (LOD = 0.016 µg/L). Water monitoring data for malaoxon collected from 2008 to 2013 was

also available from the Pesticide Data Program, a national pesticide residue monitoring program conducted by the United States Department of Agriculture. Malaoxon was not detected in 1 221 samples (LOD = 0.37–600 ng/L) from groundwater sources (e.g., private wells, daycare/school wells). In raw and finished water, malaoxon was detected in 2 samples (n = 1 283) at a maximum concentration of 1.8 ng/L (finished water, LOD = 0.37–600 ng/L) (USDA, 2020).

Based on surveillance and field trial data, malathion residues in food are expected to be low and to not pose a dietary risk to Canadians (Health Canada, 2010, 2012). In Canada, the established maximum residue limits for malathion range from 0.5 to 8 ppm for various food commodities (e.g., fruits, vegetables, grains and beans/legumes) (Health Canada, 2020b). The Canadian Food Inspection Agency sampled and tested domestic and imported food products (i.e., fresh fruits and vegetables, meat, nuts and seeds) between April 1, 2015, and March 31, 2016. Malathion residues were detected in 43 samples (n = 998) at a maximum level of 0.64000 ppm (CFIA, 2019a). Among infant foods and formulas monitored by the Canadian Food Inspection Agency, 2 samples (n = 221) tested positive for malathion contamination below the maximum residue limit of 2 ppm, with levels of 0.0195 ppm and 0.0322 ppm recorded (CFIA, 2019b).

Based on its physical properties, airborne exposure to malathion is not expected to be a concern for the Canadian population, with air monitoring data indicating that malathion is only present at low levels in areas where it is used (Health Canada, 2010).

Most Canadians have very low urine levels of DCA, as measured in Cycle 3 (2012–2013) and Cycle 4 (2014–2015) of the Canadian Health Measures Survey (CHMS) (Health Canada, 2019b). In the CHMS, group geometric means of urinary DCA were not calculated if more than 40% of the samples were below the detection limit of 0.19 µg/L. Geometric means were not calculated for any sex or age group due to low detection. The 95th percentile for the total age group (3–79 years) was 1.2 µg/L (95% confidence interval (CI): 0.70–1.6 µg/L) in Cycle 3 and 0.95 µg/L (95% CI: 0.46–1.4 µg/L) in Cycle 4.

2.0 HEALTH CONSIDERATIONS

All pesticides, including malathion, are regulated by Health Canada's PMRA. PMRA conducts extensive evaluations and cyclical reviews of pesticides, including unpublished and proprietary information, as well as foreign reviews by other regulatory agencies such as the United States Environmental Protection Agency (U.S. EPA). As such, this health



assessment is primarily based on PMRA evaluations (Health Canada, 2003, 2010, 2012) and supporting documentation. Any reviews and relevant literature available since the PMRA evaluations were completed were also considered.

2.1 Kinetics

Absorption: Following oral exposure, malathion is readily and rapidly absorbed from the gastrointestinal tract (mostly in the intestine) in mammals, including humans (based on excretion data), with peak plasma levels being reached 15 minutes post-dosing in rats (Reddy et al., 1989; Aston, 2000; Gillies and Dickson, 2000; Jellinek, Schwartz & Connolly Inc., 2000; ATSDR, 2003; EFSA, 2009; Health Canada, 2010; IARC, 2017; WHO, 2017a). Dermal absorption of malathion occurs readily and is expected to be slower than oral absorption and varied among species, with rabbits demonstrating a substantially greater capacity for dermal absorption of malathion (e.g., 64.6% for rabbits, 15.5% for pigs in vitro, 6% for rats and 0.2%–8.2% for humans) (ATSDR, 2003; Gervais et al., 2009; Health Canada, 2010; WHO, 2017a).

Distribution: Malathion is rapidly distributed in the body, with no evidence of bioaccumulation (Health Canada, 2010). In human volunteers, no malathion nor malaoxon was detected in plasma at 1–12 hours following the administration of a single oral dose (LOD = 100–102 and 99.8–100 ng/ml, respectively) (Aston, 2000; Gillies and Dickson, 2000; Jellinek, Schwartz & Connolly Inc., 2000). In rats gavaged with ¹⁴C-malathion, less than 1.5% of the administered dose was detected in the tissues at 72 hours, with the highest concentration observed in the liver, followed by skin, fat, bone and gastrointestinal tract (Reddy et al., 1989).

Metabolism: Following oral exposure in rats and humans, malathion is fully metabolized, with no parent compound present in urine (Reddy, 1989; ATSDR, 2003; Health Canada, 2010; WHO, 2017a). The major metabolic pathway for both malathion and malaoxon is hydrolysis by tissue, liver or plasma carboxylesterases, resulting in the production of MCA and DCA metabolites (> 80% in rats) (Health Canada, 2010). Unlike rats, humans have no detectable levels of carboxylesterases in serum, plasma or erythrocytes, but may have more active liver carboxylesterases (ATSDR, 2003; IARC, 2017; WHO, 2017a). Malaoxon, the active metabolite of malathion, may be formed to a lesser extent (4%–6% in rats) via oxidative desulphuration of malathion (minor pathway) by microsomal enzymes (ATSDR, 2003; Health Canada, 2010). Once formed, malaoxon is either excreted in the urine, rapidly hydrolyzed to malathion MCA and DCA, or further metabolized by phosphatases and carboxylesterase enzymes. In rats, no dose-related or sex-related differences in malathion metabolism were observed (Health Canada, 2010).

Excretion: In mammals, including humans, excretion of ingested malathion is rapid and occurs primarily in urine and to a lesser amount in feces (Reddy et al., 1989; Aston, 2000; Gillies and Dickson, 2000; Jellinek, Schwartz & Connolly Inc., 2000; ATSDR, 2003; Health Canada, 2010; WHO, 2017a). In human volunteers administered a single dose of malathion, approximately 90% of the dose was excreted in urine within 12 hours, with the entire dose excreted after 24–48 hours (Aston, 2000; Gillies and Dickson, 2000; Jellinek, Schwartz & Connolly Inc., 2000; WHO, 2017a). Malathion MCA was the most prevalent metabolite, followed by O,O-dimethyl phosphorothiolate, malathion DCA, dimethyl phosphate and dimethyl dithiophosphate (U.S. EPA, 2016; WHO, 2017a). In the rat, 76%–88% of excretion occurred in urine within 72 hours of dosing (mainly as malathion MCA and DCA), whereas 6%–14% occurred in feces. The excretion profile was similar for single or repeat low dose or single high dose administration in rats, with no sex differences reported (Health Canada, 2010).

2.2 Health effects

The toxicology database for malathion is adequate, covering several endpoints and various types of exposures (see ATSDR, 2003; IARC, 2017; WHO, 2017a for more thorough reviews). Signs of acute toxicity due to malathion exposure are consistent with ChE inhibition (tremors, convulsions, salivation and dyspnea) and were observed in a variety of species and by all routes of exposure. Young animals showed greater sensitivity to the effects of malathion on erythrocyte ChE than adults. From repeated-dose studies with malathion, the increase in severity of chronic progressive nephropathy in rats is considered the most sensitive adverse effect. Malathion was not found to be genotoxic or teratogenic in animal studies. It is unlikely to possess carcinogenic potential or pose a carcinogenic risk for humans based on its current registered use (Health Canada, 2010, 2021a).

2.3 Effects in humans

No human effects were discussed in PMRA assessments or their supporting documents (U.S. EPA, 2009; Health Canada, 2010, 2012). Studies were available from the literature concerning both cancer and non-cancer endpoints.

Agricultural Health Study: The Agricultural Health Study (AHS) is a large, ongoing questionnaire-based prospective cohort study of licensed pesticide applicators and their spouses (over 89 000 participants) who live in Iowa and North Carolina that investigates cancer and non-cancer endpoints. It began in 1993 with the collection of baseline information on farming practices (including pesticide use), lifestyle and health. Follow-up interviews/questionnaires (including dietary information) and DNA collection were done periodically. Cancer registries were used to assess cancer incidence. Overall, strengths of



the AHS include its large size; the inclusion of a large number of women; the collection of baseline, health and lifestyle information and genetic factors; the use of cancer registries and the many different pesticides and diseases assessed. Its limitations include the indirect assessment of exposure (questionnaires), the lack of exposure refinement measurements (no induction time or latency discussion) and selection bias when controlling for multiple confounders due to the exclusion of many subjects with missing data (Sathiakumar et al., 2011).

Cancer: Several investigators have published studies based on their analyses of the AHS cohort data. No associations were observed between exposure to malathion and the incidence of colorectal cancer (Lee et al., 2007), pancreatic cancer (Andreotti et al., 2009) and childhood cancer (Flower et al. 2004). Lerro et al. (2015) reported a significant increase in thyroid cancer incidence among AHS spouses, but also indicated they failed to control for exposure to elevated nitrate levels in food and drinking water, which has been proposed to play a role in thyroid cancer development in agricultural regions. Although Engel et al. (2005) reported no increased risk of breast cancer in spouses enrolled in the AHS who had used malathion themselves, an association was noted in wives whose husbands had used the pesticide. The inconsistencies in findings may be due to limitations such as self-reported exposure and the potential for exposure to multiple pesticides (WHO, 2017a). In case-control analyses by Mills and Yang (2005) and Mills et al. (2019), an elevated risk of breast cancer was observed in Hispanic agricultural workers who had used malathion. Findings in these studies were difficult to interpret, as the number of exposed cases were either not mentioned or were small. In Mills et al. (2019), the response fraction for controls was only 3% compared to 66% for cases, while in Mills and Yang (2005), the response rate was not reported. Although pesticide exposure estimates in both studies used an ecological exposure assessment method and were obtained through record linkages, thus avoiding recall bias, the use of pesticide use reports rather than individual pesticide exposure data may have resulted in exposure misclassification (IARC, 2017).

In examining AHS data from 1993 to 2007, Koutros et al. (2013) reported a significant increase in aggressive prostate cancer risk in the highest malathion exposure category, but found no association between total prostate cancer and malathion exposure. In a case-control study, Mills and Yang (2003) also found no evidence of an association between total prostate cancer and malathion exposure among Californian farm workers. However, the data may have been subject to misclassification as the classification of exposure was based on ecological rather than individual exposure (IARC, 2017; WHO, 2017b). In contrast, Band et al. (2011) reported a correlation between malathion usage and total prostate cancer in British Columbian farmers, with significant dose-response effects. However, pesticide exposures were assessed using a job-exposure matrix and were susceptible to misclassification; also, the data were not corrected for multiple pesticide exposure (Band et al., 2011; IARC, 2017; WHO, 2017b).

Based on the AHS cohort data, no increased risk of non-Hodgkin's lymphoma (NHL) was observed in male pesticide applicators using malathion, while a decreased association was observed in spouses of applicators using the pesticide (Alavanja et al., 2014; Lerro et al., 2015). Investigating agricultural cohorts from France and Norway and from AHS in the United States, Leon et al. (2019) also reported a lack of association between malathion use and risk of NHL; although there is a possibility of exposure misclassification due to the use of "crop-exposure matrices" to estimate exposures. In contrast, a cross-Canada, population-based, case-control study demonstrated a significant association between NHL and "ever use" of malathion in comparison to "never use" and for annual days of use amongst men in a diversity of occupations (McDuffie et al., 2001). A similar association was reported in pooled data from three United States Midwestern case-control studies; however, the association was attenuated or no longer significant upon removal of proxy respondents from the analyses and more robust adjustments for other pesticides (Waddell et al., 2001; De Roos, 2003; WHO, 2017b). Koutros et al. (2019) further evaluated the potential link between malathion exposure and NHL using pooled data from the cross-Canada study and the three United States Midwestern studies. A significantly increased risk of NHL was observed among "ever users" of malathion compared to "never users" after adjustment for use of other pesticides, as well as an association between malathion use and certain NHL subtypes. Analyses of the pooled data also demonstrated a significant exposure-response relationship with years of malathion use (Koutros et al., 2019). While the larger dataset considered by Koutros et al. (2019) allowed for a more powerful assessment, limitations attributable to the individual case-control studies (e.g., recall bias, use of proxy respondents) create a potential for exposure misclassification.

Although positive associations have been observed between exposure to malathion and certain cancers, most notably NHL, no associations have been seen in other studies for the same cancer endpoint making the findings difficult to interpret. Study limitations (e.g., small number of cases, failure to control for confounders, use of proxy respondents, recall bias and potential for exposure misclassification) and the limited number of populations studied may account for some of the inconsistencies between different study findings and preclude definitive conclusions on the relationship between exposure to malathion and cancer risk.

Non-Cancer: In evaluating non-cancer endpoints in the AHS cohort data, investigators have reported respiratory effects, including wheeze, chronic bronchitis symptoms (occurring with and without chronic obstructive pulmonary disease) and adult onset of allergic asthma in females and non-allergic asthma in males related to malathion exposure (Hoppin et al., 2002, 2006, 2008, 2009; Rinsky et al., 2019). Kamel et al. (2007) did not find a strong association between Parkinson's disease and exposure to malathion in the AHS. In studies evaluating the associations between "ever usage" of malathion and incidence of diabetes, no association was observed among farmers or their wives (Montgomery et al.,



2008; Starling et al., 2014). Goldner et al. (2010, 2013) observed no significant association between “ever use” of malathion and hypothyroidism in either male applicators or their female spouses in the AHS based on data collected up to 2010. However, follow-up studies by Shrestha et al. (2018, 2019) using AHS data up to 2016, reported an increased risk of incidence of hypothyroidism and a reduced risk of hyperthyroidism with malathion exposure.

In a controlled ingestion study, groups of five male volunteers were administered malathion-containing capsules (purity not specified) in doses of approximately 0.11 mg/kg body weight (bw) per day for 32 days, 0.23 mg/kg bw per day for 47 days, or 0.34 mg/kg bw per day for 56 days (Moeller and Rider, 1962; ATSDR, 2003). No significant decrease of plasma or erythrocyte activity or changes in blood counts or urinalyses resulted from the administration of 0.11 mg/kg bw per day of malathion for 32 days or 0.23 mg/kg bw per day for 47 days. Volunteers receiving 0.34 mg/kg bw per day for 56 days of malathion were observed to have a maximum 25% decrease in plasma ChE and erythrocyte ChE in absence of clinical signs (Moeller and Rider, 1962; ATSDR, 2003). The Moeller and Rider (1962) study was considered to be of poor quality owing to the inadequate reporting detail and limited protocol, including the use of small group sizes, extended exposure durations (32 to 56 days), and the apparent treatment of volunteers with other chemical substances. However, the study confirmed that animal species were indeed appropriate surrogates for assessing toxicity in humans as erythrocyte ChE depression was identified. This inhibition of ChE activity is corroborated by poison control center findings that associate cholinergic symptoms in humans with malathion exposure (Health Canada, 2021a).

A randomized double-blind study in human volunteers administered a single dose of malathion ranging from 0.5 to 15.0 mg/kg bw (27 male and 7 females test subjects, 11 male and 3 female controls), reported the absence of any treatment-related adverse effects on erythrocytes and plasma AChE activities and no alterations in vital signs, electrocardiograms, hematology, clinical chemistry, urinalysis and physical parameters, up to 24 or 48 hours after dosing (Gillies and Dickson, 2000). Similarly, another volunteer study examining the same dose levels administered as a single dose reported no treatment-related adverse effects on AChE activity (Jellinek, Schwartz and Connolly Inc., 2000).

Kidney injury, including nephrotic syndrome and acute renal failure, has been reported following acute inhalation and dermal exposure to malathion (Albright et al., 1983; Yokota et al., 2017).

2.4 Effects in animals

Repeat exposure studies in rats, mice, rabbits and dogs showed malathion induced primarily kidney and neurological effects although other effects have also been noted (Shellenberger and Billups, 1987; Daly, 1993a, 1993b, 1996; ATSDR, 2003; EFSA, 2009; U.S. EPA, 2009; Health Canada, 2010; Barnett Jr., 2012a, 2012b; WHO, 2017a).

Malathion has been shown to be slightly acutely toxic to experimental animals via the oral, dermal and inhalation routes. The acute toxicity of malathion depends on its purity level. Oral median lethal dose (LD_{50}) values of 2 382–8 200 mg/kg bw in rats (96.0%–99.1% purity level), 6 100 mg/kg bw in female mice (95% purity level) and > 4 000 mg/kg bw in dogs (98% purity level) were reported for malathion. Dermal LD_{50} values for malathion were > 2 000 mg/kg bw in rats (96%–98% purity level) and 8 900 mg/kg bw in rabbits (95.6% purity level). An inhalation medial lethal concentration (LC_{50}) value of > 5.2 mg/L in rats (96%–98% purity level) was also reported for malathion (FAO/WHO, 1997; Decker et al., 2003; U.S. EPA, 2009; Health Canada, 2010).

Kidney effects: Nephrotoxicity has been observed in rats and beagle dogs following oral administration (all durations of exposure) of malathion.

In a 24-month chronic toxicity/carcinogenicity study, groups of Fischer 344 rats (90/sex/dose) were administered malathion (97.1% pure) in the diet at doses of 0, 100/50 (reduced day 113), 500, 6,000 or 12 000 ppm (equivalent to 0, 2.4, 26, 327 or 677 mg/kg bw per day in males and 0, 3.0, 32, 386 or 817 mg/kg bw per day in females). Interim sacrifices (10–15/dose/sex) were performed at 3, 6 and 12 months (Daly, 1996). At 12 months and at terminal sacrifice, kidney weights (absolute, relative to body brain weights) were statistically significantly increased in both male and female rats at $\geq 6 000$ ppm ($\geq 327/386$ mg/kg bw per day in males/females). Macroscopic findings at the end of the study included increased incidence of irregular surfaces of the kidneys at 500, 6 000 and 12 000 ppm (26, 327 and 677 mg/kg bw per day) in males and at 12 000 ppm (817 mg/kg bw per day) in females (U.S. EPA, 1997). An increased severity of chronic progressive nephropathy was observed in both sexes, that is, in females administered ≥ 500 ppm (≥ 32 mg/kg bw per day) of malathion and males administered $\geq 6 000$ ppm (327 mg/kg bw per day), with the males also demonstrating an earlier onset of the disease at interim sacrifice (Health Canada, 2010).

Similar effects have been observed in sub-chronic toxicity studies with higher doses of malathion in both beagle dogs and rats. In a 52-week oral study, beagle dogs (6/sex/dose) were administered 62.5–250 mg/kg bw per day of malathion (95% pure) in capsules. At doses of ≥ 62.5 mg/kg bw per day, decreases in creatinine and blood urea nitrogen levels were observed accompanied by increases in absolute and relative kidney weights (Shellenberger and Billups, 1987). In a 90-day dietary toxicity study, groups of F344 rats (10/sex/group) were administered 100–20 000 ppm (equivalent to 6.6–1 190 mg/kg bw per



day in males and 7.9–1 597 mg/kg bw per day in females) of malathion (96.4% pure). Increased relative kidney weights were observed at $\geq 340/384$ mg/kg bw per day in males/females, and increased absolute kidney weights were observed at 680 mg/kg bw per day in males and $\geq 1 597$ mg/kg bw per day in females. As well, an increased severity of chronic nephropathy was observed in males at ≥ 340 mg/kg bw per day (Daly, 1993b). In two dietary toxicity studies (28- and 29/30-day) where rats were administered malathion (95.8% and 96.4% pure, respectively), increases in relative kidney weights were observed starting at 457.5 mg/kg bw per day (Daly, 1993a; Barnett Jr., 2012a).

Toxic effects on kidney tissues were also observed in single-dose toxicity studies (≥ 100 mg/kg bw) in rats (Alp et al., 2011; Akbel et al., 2018; Selmi et al., 2018).

Neurotoxicity: Dose-related inhibition of plasma ChE, erythrocyte ChE and brain ChE activity has been observed in experimental animals (rats, mice, rabbits and beagle dogs) administered malathion by all exposure routes and for various durations of exposure (ATSDR, 2003; U.S. EPA, 2009; Health Canada, 2010; WHO, 2017a). Malathion neurotoxicity is due mainly to its activated metabolite malaoxon (see Section 2.6).

Depression of erythrocyte ChE is considered an appropriate surrogate measure of potential effects on the nervous system, while depression of plasma ChE is not considered to be a toxicologically adverse effect, but serves as a marker of exposure following exposure to malathion (Health Canada, 2010). For animals exposed to malathion, erythrocyte ChE is the most sensitive compartment for ChE inhibition and is a suitable surrogate for peripheral neurotoxic effects in acute and some short-term studies. However, in longer studies, depression of erythrocyte ChE is not considered a toxicologically adverse effect due to the limitations related to the low rate of re-synthesis of erythrocyte ChE over extended periods.

Brain ChE inhibition typically occurred at higher doses than erythrocyte ChE and plasma ChE inhibition in all species. Clinical signs commonly associated with organophosphate exposure, including salivation, tremors, prostration and hypoactivity, were observed in repeat-dose studies at doses of malathion starting from 150 mg/kg bw per day (Health Canada, 2010). Assessment of the relative sensitivity of ChE activity with oral dosing reveals no appreciable species differences between mice, rats and dogs. Similarly, studies conducted via all exposure routes do not suggest a sex difference in sensitivity to the effects of malathion on ChE inhibition (Health Canada, 2010).

However, the current neurotoxicity database suggests that pre-weanling rats are more susceptible than adult rats to the neurotoxic effects of malathion following exposure from the oral route. Finally, neuropathological changes were not observed in the majority of mammalian toxicity studies. However, several isolated incidences of neuropathological changes have been observed in two rat studies at very high doses (1 500 mg/kg bw per day) in only one sex (males) and are considered equivocal (Health Canada, 2010).

In the 24-month chronic toxicity/carcinogenicity study by Daly (1996) where Fischer 344 rats (90/sex/dose) were fed diets containing 50–12 000 ppm (equivalent to 2.4–677 mg/kg/bw per day for males and 3.0–817 mg/kg bw per day for females) of malathion (97.1% pure), decreases in plasma ChE activity were observed at ≥ 500 ppm ($\geq 26/32$ mg/kg bw per day in males/females) while erythrocyte ChE and brain ChE activities were decreased at $\geq 6 000$ ppm ($\geq 327/386$ mg/kg bw per day in males/females). In an 18-month dietary carcinogenicity study where malathion (96.4% pure) was administered to B6C3F1 mice (65/sex/group), decreases in plasma ChE and erythrocyte ChE activities were observed at $\geq 143/167$ mg/kg bw per day (lowest dose tested) in males/females and decreases in brain ChE were observed at $2 978/3 448$ mg/kg bw per day (highest dose tested) in males/females (Health Canada, 2010).

In sub-chronic oral toxicity studies with malathion (95%–96.4% pure), inhibition of erythrocyte ChE, plasma ChE and/or brain ChE was observed at dose levels as low as 7.9 mg/kg per day (rats), 62.5 mg/kg bw per day (dogs) and 250 mg/kg bw per day (dogs), respectively (Shellenberger and Billups, 1987; Daly, 1993a; 1993b; Barnett Jr., 2012a, 2012b). In a 21-day dermal toxicity study in rabbits (10/sex/group), inhibition of erythrocyte ChE occurred at ≥ 75 mg/kg bw per day of malathion (96% pure) (lowest dose tested) and inhibition of plasma ChE and brain ChE occurred at 500 mg/kg per day (highest dose tested) (Health Canada, 2010).

In an acute delayed neurotoxicity study (gavage) using 12 hens, there was no evidence of delayed type neuropathology caused by the administration of malathion (EFSA, 2009; Health Canada, 2010; WHO, 2017a).

In a developmental neurotoxicity study, dose levels of 0, 5, 50 or 150 mg/kg bw per day of malathion (96.0% pure) in corn oil were administered (gavage) to 24 dams from gestational day (GD) 6 to postnatal day (PND) 10 and from PND 11 to 21 to the pups. At the highest dose, clinical signs were observed in the dams (post-dosing salivation) and the pups (e.g., tremors, hypoactivity, prostrate posture, partially closed eyelids). Also in the pups, increased incidence of flattened gait (PND 60, males) and decreased motor activity (PND 17/22, females) were observed at ≥ 50 mg/kg bw per day. In a comparative ChE rat study, adults and PND 11 pups (8/sex/group) were treated (gavage) with 0, 5, 50, 150 or 450 mg/kg bw of malathion (96.0%) for one day. Repeated exposure by gavage (11 days) was also assessed in this study using similar doses in adults and PND 11–21 pups (8/sex/group), in 19 adult females (9 females treated GD 6–20, 10 females treated GD 1–10) and in pups (2/sex/litter/group) sacrificed 4 hours after dosing of the dam at PND 4. The results of the study showed that, at similar dose levels, PND 11 and PND 21 pups are more sensitive than are adult animals to the ChE-inhibiting effects of malathion. Benchmark dose calculations (using a benchmark dose response of 20% for erythrocyte ChE) suggest that the young animals are approximately 6.4 times and 1.8 times more sensitive to the ChE inhibiting effects of malathion compared to adults following acute and repeat dose oral exposure, respectively (Health Canada, 2010).



Reproductive/developmental toxicity: Malathion did not induce reproductive toxicity in rats at the highest dose tested, while fetotoxic effects occurred only at maternally toxic doses in rats and rabbits (Health Canada, 2010).

In a two-generation (2 litters/generation) dietary reproductive toxicity study, Sprague-Dawley rats (25/sex/group) were administered 550–7 500 ppm (equivalent to 43–612 mg/kg bw per day in males and 51–703 mg/kg bw per day in females) of malathion (94% pure). No effect on the reproductive parameters or reproductive tissues was observed. However, decreases in weight gain in the parental rats (F0) (during gestation and lactation [females]) and in the first generation – first litter (F1) (during pre-mating) were observed at the highest dose. Decreased weights were observed in some first- and second-generation pups (1 of 2 litters in each generation) at PND 21 at 394/451 mg/kg bw per day in males/females and in all second generation pups (4 litters) at the highest dose tested (Health Canada, 2010). In 80-week and 103-week feeding studies, no treatment-related gross or microscopic alterations in the prostate or testis of male rats or histopathological alteration in the mammary gland, uterus or ovaries of female rats were observed following the administration of up to 622 mg/kg per day and 332 mg/kg per day of malathion (95% pure), respectively (NCI 1978, 1979). Similar results were noted in male mice administered in the diet up to 2 980 mg/kg per day of malathion (95% pure) for 80 weeks; however, in the females, an increased incidence of cystic endometrial hyperplasia was observed following administration of 1 490 mg/kg bw per day of malathion (95% pure) for 80 weeks (NCI, 1978).

Malathion was evaluated for developmental toxicity in rats and rabbits. Following administration (gavage) to pregnant rabbits (20/group) of 25–100 mg/kg bw per day of malathion (95% pure) on GD 6–18, a slightly increased incidence of dams with resorptions (embryo-fetal loss) was observed at ≥ 50 mg/kg per day in the presence of maternal toxicity (decreases in weight gain during dosing). When malathion (94% pure) was administered by gavage to pregnant Sprague-Dawley rats (24–25/group, 200–800 mg/kg per day, GD: 6–15), a slightly increased incidence of dams with resorption sites was also observed at the highest dose in the presence of maternal toxicity. Maternal toxicity included red lacrimal secretion, discharge of a pigmented secretion from the nose, urine staining of abdominal fur and decreases in weight gain and food consumption during dosing. Neither developmental study showed evidence of treatment-induced malformations (Health Canada, 2010).

Other effects: Reported treatment-related effects including increases in liver and thyroid/parathyroid weights have been observed at 62.5 mg/kg bw per day and greater in dogs, and liver effects were also observed in rats following repeated oral exposure, with non-cholinergic hematological effects being observed at higher dose levels (Shellenberger and Billups, 1987; Daly, 1996; Health Canada, 2010).

Non-neoplastic liver changes were observed in experimental animals but may represent adaptive responses. However, more serious histopathological damage may be observed in the liver with high single doses of malathion (ATSDR, 2003).

There is insufficient evidence to indicate that malathion affects the endocrine system; however, there is some indication that malathion may elicit an immune response in experimental animals by affecting both humoral and cellular immunity based on findings from published studies (Health Canada, 2010).

2.5 Genotoxicity and carcinogenicity

Based on an extensive review of available published and unpublished scientific evidence, including proprietary information, the PMRA did not consider malathion to be genotoxic or carcinogenic (Health Canada, 2010, 2012, 2015, 2021a).

Overall, the database for malathion did not indicate that malathion has genotoxic potential based on the weight of evidence. Although some in vitro and in vivo genotoxicity studies reported positive findings in the published literature, the relevance of these findings is unclear since the positive results were typically noted at levels that were cytotoxic. In addition, the identity and/or purity of the test substance was not always stated in the positive genotoxicity studies (Health Canada, 2010, 2021a; WHO, 2017a).

In in vitro studies, malathion was not mutagenic in bacteria (Ames tests using several bacterial strains, with and without metabolic activation) or in yeast (*Saccharomyces cerevisiae* gene mutation assay) and did not cause unscheduled DNA synthesis (UDS) in cultured rat hepatocytes (U.S. EPA, 1977; Traul, 1987; Pluth et al., 1996; U.S. EPA, 2009; Health Canada, 2010; IARC, 2017; WHO, 2017a). Some in vitro genotoxicity assays (Comet, DNA-protein-crosslinking, sister-chromatid exchange) reported positive results, although only at high malathion doses (i.e., cytotoxic doses) or while using a test material of unspecified purity (Chen et al., 1981; Nishio and Uyeki, 1981; Health Canada, 2010; Ojha and Srivastava, 2014; Ojha and Gupta, 2015; IARC, 2017; WHO, 2017a).

In animals in vivo, malathion did not cause mutations in spermatogonia of mice (dominant lethal assay), or chromosomal aberrations in bone marrow of rats (Health Canada, 2010; IARC, 2017; WHO, 2017a). In contrast, other rodent studies detected chromosomal aberrations and DNA damage (as assessed by the Comet assay) following oral administration of malathion at either cytotoxic doses or while using a test material of unspecified identity and/or purity (Dulout et al., 1983; Giri et al., 2002; Health Canada, 2010; Ojha et al., 2013; IARC, 2017).



In human cells, malathion did not cause UDS in lung fibroblasts, but induced mutations in T lymphocytes in the HRPT assay and 8-OH-dG adduct formation in human peripheral blood mononuclear cells (U.S. EPA, 1977; Pluth et al., 1996; Ahmed et al., 2011). Mixed results were reported for sister chromatid exchange and DNA damage (assessed by the Comet assay), with positive findings observed only at near cytotoxic to cytotoxic doses, or with malathion of unspecified purity (Blasiak et al., 1999; Health Canada, 2010; Moore et al., 2010; Olakkaran et al., 2020). Chromosomal aberrations were observed in human peripheral leukocytes, but with test material of unspecified purity (Health Canada, 2010). An increase in micronucleated cells was found in cultured lymphocytes treated with high doses of malathion; however, in vivo studies with agricultural workers exposed specifically to malathion reported negative results for both micronuclei formation and glycophorin A mutations in peripheral lymphocytes of the cohorts examined (Titenko-Holland et al., 1997; Windham et al., 1998).

Overall, the database for malathion did not suggest that malathion has carcinogenic potential for humans based on the weight of evidence (Health Canada, 2010, 2015, 2021a).

In an 18-month study where B6C3F1 mice were fed malathion at 100–16 000 ppm, an increased incidence of benign liver tumours (adenomas) was observed in both sexes at 8 000 ppm (1 476 mg/kg bw per day for males, 1 707 mg/kg bw per day for females) and 16 000 ppm (2 978 mg/kg bw per day for males, 3 448 mg/kg bw per day for females) (Slauter, 1994). In another study where F344 rats were given 100–12 000 ppm of malathion in the diet for 24 months, an increased incidence of liver adenomas was also noted but only in females at 12 000 ppm (817 mg/kg bw per day) (Daly, 1996). However, the maximum tolerated dose was exceeded at the dose levels at which the liver tumours were observed in the chronic toxicity/carcinogenicity studies by Slauter (1994) and Daly (1996), as demonstrated by increased mortality and decreased body weight gain observed in these dose groups. Further, there was no evidence of progression from non-neoplastic (such as hyperplasia) to neoplastic lesions. All of the identified tumours noted following exposure to malathion were classified as benign and no progression from benign to malignant tumours was observed. No dose-response relationship in tumour incidence was observed at dose levels below those deemed to be excessively toxic. As well, evidence of a decrease in tumour latency was not observed following exposure to malathion. Although liver tumours were reported in mice, the liver is the site of metabolism of malathion and demonstrated signs of metabolic saturation. Furthermore, liver tumours are a common neoplasm in mice. The organophosphates are not, generally speaking, known to be carcinogenic (Health Canada, 2010, 2012, 2021a). In the 24-month rat study, Daly (1996) also reported solitary rare nasal and oral tumours at 6 000 and 12 000 ppm in rats; however, these tumours could not be distinguished as treatment-related or caused by random

occurrence (Health Canada, 2010, 2021a). Further evaluations by peer reviewers and some regulatory agencies concluded that the nasal tumours resulted from irritation of the nasal epithelium from either volatilization or inhalation of very high concentrations of malathion from the feed (U.S. EPA, 2000a; Jensen and Whatling, 2010; FAO/WHO, 2016).

Overall, the PMRA did not consider malathion to be genotoxic based on an examination of the full weight of evidence available to the PMRA, including unpublished and proprietary information (Health Canada, 2010, 2021a). Using a risk-based approach, PMRA concluded malathion is unlikely to possess carcinogenic potential for humans (Health Canada, 2010, 2021a). The U.S. EPA has classified malathion as having “suggestive evidence of carcinogenicity but not sufficient to assess human carcinogenic potential”, while the European Food Safety Agency did not propose a classification with regard to the carcinogenicity of malathion (FIFRA, 2000; EFSA, 2009; U.S. EPA, 2009). Although IARC classified malathion as “probably carcinogenic to humans” (Group 2A), IARC uses a hazard-based approach which does not take into consideration the levels of human exposure, in contrast to the risk-based approach used by Health Canada (IARC, 2017; Health Canada, 2021a). Pesticides are registered for use in Canada only if risks to human health are acceptable, meaning that the level of exposure to Canadians does not cause any harmful effects, including cancer (Health Canada, 2015; Health Canada, 2021a).

2.6 Mode of action

Malathion was found to increase oxidative stress markers and creates an imbalance in antioxidant status in different tissues. This causes tissue injuries, including lipid peroxidation, DNA damage, and/or changes in antioxidant enzyme (Akhgari et al., 2003; IARC, 2017; Akbel et al., 2018; Selmi et al., 2018). This mode of action could explain the nephrotoxicity observed in rats and dogs following malathion exposure that was reported in some studies presented in Section 2.4 (Akbel et al., 2018; Selmi et al., 2018; Gyuraszova et al., 2019; Obert and Frazier, 2019).

In mammals, malathion undergoes metabolic activation to form malaoxon, a minor metabolite. Malathion and malaoxon both have the ability to inhibit plasma ChE, erythrocyte ChE and brain ChE activity via phosphorylation of the active site of the enzyme, although malaoxon is noted to have a higher potency compared to malathion for ChE inhibition (ATSDR, 2003; Krstic et al., 2008; Health Canada, 2010; Jensen and Whatling, 2010). The ChE enzyme is responsible for the hydrolysis of the neurotransmitter acetylcholine. Therefore, its inhibition causes acetylcholine to accumulate in the synapses, overstimulating the nicotinic and muscarinic receptors in the central and/or peripheral nervous system. This overstimulation leads to smooth muscle contractions (e.g., abdominal cramps, glandular secretions, skeletal muscle twitching and paralysis) and possible effects on learning, memory and other behavioral parameters (ATSDR, 2003; Health Canada, 2010; Jokanovic, 2018; Naughton and Terry Jr., 2018).



2.7 Selected key study

In its proposed re-evaluation decision for the continuing registration of malathion (PRVD2010-18), Health Canada (2010) identified the kidney as the most sensitive target organ across the database. An increase in severity of chronic progressive nephropathy was observed in rats of both sexes, with the females being affected at a lower dose (32 mg/kg bw per day) than males in a chronic rat bioassay (Daly, 1996). At higher doses, chronic nephropathy has also been observed as early as 90 days in a subchronic rat study (Daly, 1993b). A comparison of the results from subchronic and chronic studies conducted with malathion demonstrates that duration of dosing has an impact on toxicity, with the chronic no-observed-adverse-effect level (NOAEL) for chronic nephropathy in the Daly study (1996) being 14-fold lower than that derived in a subchronic bioassay using the same strain of rats (Health Canada, 2010). Therefore, the chronic oral toxicity/carcinogenicity study in rats conducted by Daly (1996) was identified as the key study for the human health risk assessment of malathion in drinking water (Health Canada, 2010, 2019a, 2021a).

In the Daly (1996) study, groups of rats (90/sex/dose) were fed a diet of 0, 100/50 (reduced day 113), 500, 6 000 or 12 000 ppm (equivalent to 0, 2.4, 26, 327 or 677 mg/kg/bw per day for males and 0, 3.0, 32, 386 or 817 mg/kg bw per day for females) of malathion (97.1%) for 24 months (Health Canada, 2010). After 3 months, the lowest dose was reduced from 100 ppm to 50 ppm due to the observation of statistically significant erythrocyte ChE inhibition at 100 ppm in females (U.S. EPA, 1997; Health Canada, 2010; WHO, 2017a). Rats were checked twice a day for toxicity and mortality and examinations were performed each week. Interim sacrifices took place after 3, 6 and 12 months (U.S. EPA, 1997). Treatment-related clinical signs (i.e., anogenital staining) were observed only in females at the highest dietary dose (U.S. EPA, 1997; Health Canada, 2010). Mortality was significantly increased in males at 6 000 and 12 000 ppm (327 and 677 mg/kg bw per day) (starting at month 20 and 14, respectively) and in females at 12 000 ppm (817 mg/kg bw per day) (closer to study completion), with deaths attributed in part to chronic nephropathy (U.S. EPA, 1997; Health Canada, 2010; WHO, 2017a). Although a high incidence of chronic nephropathy was reported across all groups (including controls), a treatment-related increase in severity of the effect was observed in females exposed to ≥ 500 ppm (≥ 32 mg/kg bw per day) and males exposed to $\geq 6 000$ ppm (≥ 327 mg/kg bw per day), with males also demonstrating an earlier onset of the disease at interim sacrifice (U.S. EPA, 1997; Health Canada, 2010). Decreased body weights and increased food consumption was recorded for both sexes at $\geq 6 000$ ppm ($\geq 327/386$ mg/kg bw per day in males/females), along with increased absolute and relative liver weights and kidney weights. Lesions of the nasal mucosa (degeneration and hyperplasia of the olfactory epithelium), nasopharynx irritation (inflammation and hyperplasia of the respiratory epithelium) were reported in both sexes at $\geq 6 000$ ppm ($\geq 327/386$ mg/kg bw per day in males/females).

Solitary oral and nasal tumours were also observed in both sexes; however, they could not be distinguished as either treatment-related or of random occurrence (oral tumours in females at $\geq 6\ 000$ ppm [≥ 386 mg/kg bw per day]; nasal tumours in females at $\geq 6\ 000$ ppm and in males at $12\ 000$ ppm [≥ 386 and 677 mg/kg bw per day, respectively]). An increase in the incidence of liver adenomas was noted in females at $12\ 000$ ppm (817 mg/kg bw per day), but not in males (Health Canada, 2010).

In both sexes, erythrocyte ChE and brain ChE inhibition was noted at $\geq 6\ 000$ ppm ($\geq 327/386$ mg/kg bw per day in males/females), while plasma ChE inhibition was noted at ≥ 500 ppm ($\geq 26/32$ mg/kg bw per day in males/females). Effects on erythrocyte and clinical chemistry parameters were observed in males and females exposed to the two highest doses.

An oral NOAEL of 3.0 mg/kg bw per day was identified based on a treatment-related increase in severity of chronic progressive nephropathy in female rats at the next dosage level of 32 mg/kg bw per day.

Although ChE inhibition was also a target of malathion toxicity, it was not the most sensitive endpoint of chronic toxicity. Across the database, dose-related inhibition of plasma, erythrocyte and brain ChE activity occurred by all routes and durations of exposure to malathion in repeat dose animal studies, including the key study. As explained in Section 2.4, depression of plasma ChE activity is not a toxicologically adverse effect, but serves as a marker of exposure to malathion. Depression of erythrocyte ChE activity in acute and short-term toxicology studies can be viewed as a surrogate for adverse peripheral neurotoxic effects. However, in studies of longer duration, depression of erythrocyte ChE is not considered informative due to limitations related to the low rate of re-synthesis of erythrocyte ChE over extended periods of time. Only brain ChE inhibition is considered adverse following longer-term exposures and occurred at higher dose levels of malathion (typically ≥ 150 mg/kg bw per day, observed at $327/386$ mg/kg bw per day in males/females in Daly (1996)) than those causing nephrotoxicity. As such, the NOAEL of 3.0 mg/kg bw per day based on a treatment-related increase in severity of chronic progressive nephropathy in female rats is considered protective of effects on ChE activity (Health Canada, 2021a).

While sensitivity of the young has been demonstrated, the most sensitive endpoint following repeat exposure (behavioural effects) to young animals occurs at doses exceeding the NOAEL for chronic nephropathy. Chronic nephropathy is a disease related to ageing and has been observed following long-term exposure in adult rats (Health Canada, 2010).



3.0 DERIVATION OF THE HEALTH-BASED VALUE

As noted above, the NOAEL of 3.0 mg/kg bw per day for increase in severity of chronic progressive nephropathy in female rats was selected as the basis for the current risk assessment. Using the NOAEL of 3.0 mg/kg bw per day, the acceptable daily intake (ADI) for malathion (Health Canada, 2010) is calculated as follows:

$$\begin{aligned} \text{ADI} &= \frac{3.0 \text{ mg/kg bw per day}}{100} \\ &= 0.03 \text{ mg/kg bw per day} \end{aligned}$$

where:

- » 3.0 mg/kg bw per day is the NOAEL based on chronic progressive nephropathy in female rats (Health Canada, 2010); and
- » 100 is the uncertainty factor, selected to account for interspecies variation (×10) and intraspecies variation (×10).

Based on the ADI of 0.03 mg/kg bw per day, a health-based value (HBV) for malathion in drinking water was derived as follows:

$$\begin{aligned} \text{HBV} &= \frac{0.03 \text{ mg/kg bw per day} \times 74 \text{ kg} \times 0.20}{1.53 \text{ L/day}} \\ &= 0.29 \text{ mg/L (290 } \mu\text{g/L)} \end{aligned}$$

where:

- » 0.03 mg/kg bw per day is the ADI calculated using a NOAEL of 3.0 mg/kg bw per day (Health Canada, 2010);
- » 74 kg is the adult body weight (Health Canada, 2021b);
- » 1.53 L per day is the daily volume of tap water consumed by an adult (Health Canada, 2021b); and
- » 0.20 is the default allocation factor since drinking water is not a major source of exposure to malathion and there is evidence of malathion in other exposure sources (i.e., low levels in food) (Krishnan and Carrier, 2013).

PMRA's use of a TAF in its risk assessment was considered a conservative approach required in the regulatory assessment to account for potential residues of malaoxon that may be present below the limit of detection. This document does not support using an additive approach (i.e., use of a TAF) for malathion and malaoxon in drinking water based on their environmental fate and available water monitoring data. Malathion can inhibit ChE but at higher doses than those causing nephrotoxicity. Although malaoxon is a more potent ChE inhibitor than malathion, malaoxon is expected to be present at negligible levels in raw and treated water in Canada.

Malaoxon is not a major transformation product of malathion in the environment. Both malathion and malaoxon are non-persistent in the environment and unlikely to leach into groundwater. As demonstrated by the extensive US water monitoring data presented in Section 1.3, malaoxon levels in groundwater and surface water were negligible. Although the conversion of malathion to malaoxon can also occur during oxidation or advanced oxidation processes during water treatment, given the low levels of exposure to malathion observed in Canadian drinking water sources (as presented in Table 3), any formation of malaoxon during water treatment is expected to be negligible.

4.0 ANALYTICAL AND TREATMENT CONSIDERATIONS

4.1 Analytical methods to detect malathion

Standardized methods available for the analysis of malathion in source and drinking water and their respective MDLs are summarized in Table 4. MDLs are dependent on the sample matrix, instrumentation and selected operating conditions and will vary between individual laboratories. These methods are subject to a variety of interferences, which are outlined in the respective references.

A number of accredited laboratories in Canada were contacted to determine MDLs and MRLs for malathion analysis and the MDLs were in the same order of magnitude as those reported in Table 4. The MRLs ranged between 0.02 to 5 µg/L for Gas Chromatography with Mass Spectrometry Detection (GC/MS) (AGAT Laboratories Ltd., 2019; ALS Environmental, 2019; CARO Analytical Services – Richmond Laboratory, 2019; Element Materials Technology Canada Inc., 2019; and SGS Environmental Services, 2019).



The MDLs or MRLs from provincial and territorial data range from 0.0001 to 15 µg/L (see Section 1.3).

Drinking water utilities should discuss sampling requirements with the accredited laboratory conducting the analysis to ensure that quality control procedures are met and that MRLs are low enough to ensure accurate monitoring at concentrations below the MAC. Sample processing considerations for the analysis of malathion in drinking water (e.g., sample preservation, storage) can be found in the references listed in Table 4. Additionally, a non-standardized method to analyse malathion in water based on high performance liquid chromatography with tandem mass spectrometry is presented in Rocha et al. (2015).

It is important to note that quenching is critical if an oxidant is present in samples in order to reduce additional degradation of malathion. Malathion has limited stability due to hydrolysis, with decreased half-life at increased pH and temperature (Wolfe et al., 1977; EFSA, 2006). As such, cooling of the samples and rapid analysis are recommended.

TABLE 4: Standardized methods for the analysis of malathion in water

Method (Reference)	Methodology	MDL (µg/L)	Interferences/comments
EPA 527 Rev. 1.0 (U.S. EPA, 2005)	Capillary column gas chromatography/mass spectrometry (GC/MS)	0.057 ^a	Method and matrix interferences; Contamination carryover
EPA 1699 (U.S. EPA, 2007)	High Resolution GC/MS	0.0003 (296 pg/L)	Method and matrix interferences
EPA 8141B Rev. 2 (U.S. EPA, 2000b)	Gas Chromatography with Flame Photometric Detector (GC/FPD)	5.5	Method and matrix interferences
EPA 8270D Rev. 4.0 (U.S. EPA, 1998)	GC/MS	50 ^b	Method and matrix interferences; Contamination carryover
O-1104 (USGS, 1983a)	GC/FPD	0.01 ^c	Method and matrix interferences; Sulfur and organosulfur will interfere
O-1126-95 (USGS, 1995)	GC/MS	0.005	Method and matrix interferences
O-1402-01 (USGS, 2001)	GC/FPD	0.005	Method and matrix interferences; Sulfur and organosulfur and unknown organophosphate compounds will interfere

Method (Reference)	Methodology	MDL (µg/L)	Interferences/comments
O-3104 (USGS, 1983b)	GC/FPD	0.01 ^c	Method and matrix interferences; Sulfur and organosulfur compounds will interfere
O-3402-03 (USGS, 2003)	Gas Chromatography (Unspecified Detector)	0.0040	Method and matrix interferences; Sulfur and organosulfur and unknown organophosphate compounds will interfere

MDL: method detection limit.

^a Detection limit.

^b Estimated quantitation limit.

^c MDL is estimated.

4.2 Treatment considerations

Treatment technologies available to effectively decrease malathion concentrations in drinking water include activated carbon, membrane processes, oxidation and advanced oxidation processes. Published data on malathion removal in water using these technologies indicates a large range of removal efficiencies (less than 50% up to approximately 100%) (Chian et al., 1975; Roche and Prados, 1995; Kiso et al., 2000; Duirk et al., 2009; Zhang and Pagilla, 2010; Beduk et al., 2012; Chamberlain et al., 2012; Fadaei et al., 2012; Sorour and Shaalan, 2013; Jusoh et al., 2014; Li et al., 2016). At the residential scale, certified treatment devices relying on reverse osmosis (RO) or activated carbon adsorption are expected to be effective for removal of malathion.

4.2.1 Municipal-scale

The selection of an appropriate treatment process for a specific water supply will depend on many factors, including the raw water source and its characteristics, the operational conditions of the selected treatment method and the utility's treatment goals. Bench or pilot testing is recommended to ensure the source water can be successfully treated and optimal process design is established.

When using oxidation or advanced oxidation processes (AOP) for pesticide removal in drinking water, it is important to be aware of the potential for formation of by-products due to degradation of the target compound (Ikehata and Gamal El-Din, 2006; Beduk et al., 2012; Li et al., 2019). Malathion has several degradation by-products that may form through oxidation (see Section 4.2.1.4) or advanced oxidation processes (see Section 4.2.1.5), including malaoxon, which is of health concern. The primary objective should be removal of the pesticide with the secondary objective being the minimization of by-product formation. In addition, water utilities should consider the potential for the formation of disinfection by-products depending on the oxidant selected and the source water quality.



4.2.1.1 Conventional treatment

Conventional filtration (chemical coagulation, clarification and rapid sand filtration) and chlorine disinfection may reduce malathion concentrations through oxidation during the disinfection step depending on the oxidant (Roche and Prados, 1995; Duirk et al., 2009; Beduk et al., 2012; Chamberlain et al., 2012). However, degradation processes like oxidation result in the formation of by-products, such as malaoxon (see Section 4.2.1.4).

A bench-scale study evaluated chemical coagulation and sedimentation treatment technologies for the removal of both malathion and malaoxon (Matsushita et al., 2018). The study used river water and the results showed no removal (see Table 5).

TABLE 5: Malathion and malaoxon removal via coagulation, flocculation and sedimentation (Matsushita et al., 2018)

Parameter	Influent (µg/L)	Coagulant	Dose	Removal	Process Description
Malathion	10	Polyaluminum chloride	1.0 and 1.4 mg/L	0	Bench-scale: River water at 20°C; 1L; final pH of 7.0
Malaoxon	10			0	Dosed with coagulant; rapid stir (61 rpm) for 1 min; slow stir (13 rpm) for 10 min; rest for 60 min

A bench-scale study was conducted to evaluate the cumulative removal of malathion through coagulation, flocculation and filtration followed by chlorination (see Table 6) (Costa et al., 2018). The first part of this study differed from the previous study with the addition of a filtration step and showed 62.21% removal of malathion. The removal increased further after chlorination and the authors noted the formation of malaoxon.

TABLE 6: Removal of malathion through coagulation, flocculation, filtration followed by chlorination (Costa et al., 2018)

Influent (mg/L)	Treatment Type	Cumulative Removal	Process Description	Overall Description
0.48	Coagulation, flocculation, filtration	62.21 ± 0.01%	Dosed with 20 mL aluminum sulphate at 1% (w/v); rapid mix (100 rpm) for 3 min; slow stir (50 rpm) for 10 min; rest for 15 min; filtration by gravity with 125 mm filter paper	Bench-scale: Jar tests Ultra-pure water; 1L at 100 NTU; pH 10.5
	Chlorination	73.2 ± 0.2%	Chlorine (dose = 5 mg/L)	Coagulation, flocculation, filtration followed by chlorination Note: after post chlorination, malaoxon was detected (concentration not provided)

4.2.1.2 Activated carbon adsorption

Activated carbon adsorption is a widely used technology to reduce the concentration of micropollutants, including a wide range of pesticides, in drinking water (Haist-Gulde and Happel, 2012; van der Aa et al., 2012). Activated carbon can be applied in two ways: slurry applications using powdered activated carbon (PAC) or fixed-bed reactors with granular activated carbon (GAC) (Chowdhury et al., 2013).

Data generated through bench-scale testing to determine adsorption coefficients for pesticides are useful in predicting whether activated carbon adsorbs a particular pesticide (U.S. EPA, 2011). In general, pesticides with an adsorption capacity constant (e.g., Freundlich coefficient) greater than $200 \mu\text{g/g(L}/\mu\text{g)}^{1/n}$ are considered to be amenable to removal by carbon adsorption (Speth and Adams, 1993; Speth and Miltner, 1998; U.S. EPA, 2011). However, it is important to note that the presence of natural organic matter (NOM) adds complexity to activated carbon treatment because NOM competes directly for adsorption sites or fouls the carbon by blocking pores (Chowdhury et al., 2013). Since the capacity of activated carbon can be affected by many factors, including the compound's ionic character and the solution pH, appropriate testing (e.g., jar tests, rapid small-scale column tests) should be conducted to confirm removal.

POWDERED ACTIVATED CARBON

Many pesticides have been found to strongly adsorb to PAC (Chowdhury et al., 2013). The use of PAC offers the advantage of providing virgin carbon when required (e.g., during the pesticide application season) (Miltner et al., 1989). The removal efficiency of PAC depends on the PAC characteristics (type and particle size), dose, contact time, contaminant adsorbability and NOM presence (Gustafson et al., 2003; Summers et al., 2010; Haist-Gulde and Happel, 2012; Chowdhury et al., 2013).

A bench-scale study was conducted to determine the adsorption of malathion to PAC, as well as that of malaoxon (see Table 7) (Matsushita et al., 2018). With a PAC dose of 10 mg/L, similar removal efficiencies of 69% and 76% were observed for malathion and malaoxon, respectively.

TABLE 7: Malathion and malaoxon removal via PAC (Matsushita et al., 2018)

Parameter	Influent ($\mu\text{g/L}$)	PAC Dose	pH	Remaining ratio	Removal Efficiency (%) ^a	Process Description
Malathion	10	10 mg/L	7.0	0.24 ± 0.01	76%	Bench-scale: River water 10 minute contact time
Malaoxon	10			0.31 ± 0.03	69%	

PAC: powdered activated carbon.

^a Calculated from remaining ratio.



GRANULAR ACTIVATED CARBON

The use of GAC is an effective approach for treating organic contaminants that are regularly found in source water at concentrations of concern (Chowdhury et al., 2013). The capacity of GAC to remove pesticides by adsorption depends on the filter velocity, empty bed contact time (EBCT), the GAC characteristics (type, particle size, reactivation method), the adsorbability of the contaminant and the filter run time (Haist-Gulde and Happel, 2012). In addition, because GAC fixed-bed adsorbers are typically operated on a continuous basis, the GAC can become fouled (or preloaded) with NOM and it may be completely or partially ineffective for pesticide removal (Knappe et al., 1999; Summers et al., 2010; Haist-Gulde and Happel, 2012; Chowdhury et al., 2013).

Column experiments were conducted on two different GACs [palm shell activated carbon (PSAC) and coconut shell activated carbon (CSAC)] (Jusoh et al., 2014). The authors found that the malathion removal efficiency for CSAC was greater than that for PSAC (see Table 8). The authors also concluded that the adsorption capacity increased as flow rate decreased. In other words, removal efficiency increased with longer EBCT.

TABLE 8: Malathion removal via GAC (Jusoh et al., 2014)

Influent (µg/L)	EBCT (min)	Removal		Process Description
		CSAC	PSAC	
7	2.95	28.6%	18.6%	Bench-scale column experiments: Column diameter = 1.3 cm; Column height = 120 cm; Flow rate of 0.00012 m ³ /hr; Adsorbent particle size = 1.0 mm; Temperature = 30°C NOTE: The treated volume of water is not presented
	3.93	41.4%	31.4%	
	4.91	50.0%	42.9%	
	11.76	64.2%	47.1%	
	15.7	71.4%	60.0%	
	19.6	82.9%	71.4%	

EBCT: empty bed contact time; CSAC: coconut shell activated carbon; PSAC: palm shell activated carbon.

4.2.1.3 Membrane filtration

In general, nanofiltration (NF) and RO are effective pressure-driven membrane processes for the removal of pesticides from drinking water (Van der Bruggen and Vandecasteele, 2003; U.S. EPA, 2011). The effectiveness of NF and RO for pesticide removal is dependent on the membrane characteristics, pesticide properties, feed water composition, operating conditions and membrane fouling (Van der Bruggen and Vandecasteele, 2003; Plakas and Karabelas, 2012).

Since the main mechanism for pesticide removal using NF and RO membranes is size exclusion, the molecular weight cut-off (MWCO) of the membrane is an important characteristic. Based on the molecular weight of malathion (217 Da), membranes with a

MWCO varying between 200 and 400 Da are considered appropriate for malathion. In addition to the sieving effect, retention of small pesticide molecules by larger pore size membranes can be influenced by the physicochemical interactions between the pesticide and the membrane surface (Plakas and Karabelas, 2012).

Bellona et al. (2004) presented a flow-chart using the characteristics of the pesticide in water (e.g., molecular weight, $\log K_{ow}$, molecular diameter) and those of the membrane (e.g., MWCO, pore size) which could be used to determine the potential for removal of malathion by membrane filtration. It is important to perform appropriate testing prior to full-scale implementation with membrane and source water under the proposed operating conditions to ensure that adequate malathion removal is occurring.

Malathion removal was investigated through several bench-scale wastewater studies (see Table 9). Chian et al. (1975) used two different membranes and both achieved greater than 99% malathion rejection. A second bench-scale study by Kiso et al. (2000) investigated malathion removal using four membranes. The malathion removal using the two polyvinyl alcohol/ polyamide membranes was high (greater than 88%), whereas the removal was much lower for the membranes composed from sulfonated polyethersulfone (less than 42%). Another study had similarly high malathion removal at a trans-membrane pressure of 1 120 kPa and showed improved rejection with increased trans-membrane pressure (Zhang and Pagilla, 2010). A bench-scale study by Sorour and Shaalan (2013) showed increased rejection with increased initial malathion concentration.

TABLE 9: Malathion removal via reverse osmosis (RO) and nanofiltration (NF) from wastewater studies

Influent	Rejection	Membrane Type	Process Description	Reference
1 057.8 µg in 150 mL solution	99.65%	NS-100	Bench-scale study: Stainless steel static test cell Aqueous solution prepared from demineralized water Room temperature; Pressure = 40.8 atm (600 psig) NS-100:	Chian et al. (1975)
	99.16%	CA	Cross-linked polyethylenimine membrane; Average permeate flux = 49 ml/cm ² /day (12 gfd) CA: Cellulose acetate membrane; Average permeate flux = 32 ml/cm ² /day (8 gfd)	



Influent	Rejection	Membrane Type	Process Description	Reference
0.5–1.5 mg/L	99.64%	Memb-1	Bench-scale study; Flat sheet type membranes Memb-1: Poly(vinyl alcohol)/polyamide; NaCl rejection = 92%; $J_w^a = 0.988$ m/d; P = 1 MPa	Kiso et al. (2000)
	88.1%	Memb-2	Memb-2: Poly(vinyl alcohol)/polyamide; NaCl rejection = 60%; $J_w^a = 1.689$ m/d; P = 1 MPa	
	42.0%	Memb-3	Memb-3: Sulfonated polyethersulfone; NaCl rejection = 51%; $J_w^a = 2.435$ m/d; P = 1 MPa	
	41.4%	Memb-4	Memb-4: Sulfonated polyethersulfone; NaCl rejection = 15%; $J_w^a = 6.205$ m/d; P = 0.5 MPa	
10 mg/L	61% ^b (P = 560kPa)	NF-A	Bench-scale; synthetic wastewater NF-A: Polypiperazine amide thin-film composite; MgSO ₄ retention > 99%; Product water flux = 58.4 L/m ² ·h	Zhang and Pagilla (2010)
	98% ^b (P = 1680kPa)			
	78% ^b (P = 560kPa)	NF90	Bench-scale; synthetic wastewater NF90: Polyamide thin-film composite; MgSO ₄ retention > 97%; Product water flux = 40.5 L/m ² ·h; Pore size = 0.55 ± 0.13 nm; porosity = 17.1%	
	98% ^b (P = 1680kPa)			
	55% ^b (P = 560kPa)	NF270	Bench-scale; synthetic wastewater NF270: Polyamide thin-film composite; MgSO ₄ retention > 97%; Product water flux = 53.2 L/m ² ·h; Pore size = 0.71 ± 0.14 nm; porosity = 11.7%	
	92% ^b (P = 1680kPa)			
5.7mg/L	93.5%	NF Tubular ceramic membrane	Bench-scale study Membrane properties: Ceramic/TiO ₂ -Al ₂ O ₃ ; Tubular configuration; 0.245 m ² surface area; 1 kDa pore size Pressure = 5 bar	Sorour and Shaalan (2013)
17.1 mg/L	99.4%			

^a Pure water flux.

^b Estimated from graph.

4.2.1.4 Oxidation and hydrolysis

Chemical oxidation and hydrolysis are the most important degradation pathways for the organophosphorus pesticides under drinking water treatment conditions (Durik et al., 2006; Newhart, 2006). Degradation of malathion in water is pH dependent and it degrades quickly in water with pH > 7.0. The half-life range of malathion is 0.2 weeks in water at pH 8.0 compared to 21 weeks at pH 6.0 (Newhart, 2006). The studies examining degradation of malathion using various oxidants are presented in Table 10.

Common oxidation/disinfection processes showed a wide range of reactivity for malathion (Roche and Prados, 1995; Durik et al., 2009, 2010; Chamberlain et al., 2012). Bench-scale testing conducted with typical drinking water disinfection doses of chlorine (Cl_2) and ozone (O_3) have reported moderate to high removal of a low concentration of malathion (Chamberlain et al., 2012) (Table 10). The authors reported a greater than 50% removal of malathion using chlorination conducted at both pH levels of 6.6 and 8.6 and with an ozonation process at pH of 6.6. It was found that ozonation at pH 8.6 achieved a moderate removal ranging from 20% to 50%. Oxidants such as monochloramine (NH_2Cl), chlorine dioxide (ClO_2), permanganate (MnO_4^-), hydrogen peroxide (H_2O_2) and direct ultraviolet (UV) photolysis at 254 nm achieved less than 20% removal of malathion. Hydrolysis tests conducted at pHs 2, 7 and 12 also reported similar results (Chamberlain et al., 2012). The application of direct UV photolysis was also reported as being ineffective for the degradation of malathion by Beduk, et al. (2012) and Li et al. (2019). Direct photolysis of organophosphorus pesticides using low- and medium-pressure UV lamps was reported to be very slow with a low quantum yield, which was defined as a number of moles of the reactant being degraded per mole of photons absorbed (Wu and Linden, 2008).

The degradation efficiency of malathion is influenced by several parameters, including water matrix, ozone dose and contact time (Roche and Prados, 1995; Beduk et al., 2012). In a bench-scale ozonation test, Roche and Prados (1995) studied the effect of water alkalinity on the oxidation efficiency of eleven pesticides, including malathion. Due to the inhibiting role of carbonate species, the removal of malathion was higher in water with a low alkalinity (specific data were not provided). Ozonation tests conducted by Beduk et al. (2012) reported an increase of malathion degradation rate with an increased ozone dose and pH level of the water. A direct ozone reaction (ozonolysis) was responsible for the degradation of malathion at a low pH, while a high pH of 9.0 involved a non-selective hydroxyl radical ($\cdot\text{OH}$) formation.

Durik et al. (2009) examined the degradation of malathion in deionized water using hypochlorous acid (HOCl). The oxidation rate of malathion was rapid under the tested conditions and the oxidation efficiency strongly depends on the pH of the water. HOCl is a weak acid that dissociates to produce hypochlorite ion (OCl^-), with a dissociation constant (pKa) of approximately 7.6 at 20°C. Chlorine species in the water shift from HOCl to hypochlorite ion (OCl^-) when the pH increased from neutral to alkaline. The study reported



that OCl^- ion did not oxidize malathion to malaoxon (degradation by-product, discussed below in this section); however, it accelerated the hydrolysis of malathion. Similar experiments investigated oxidation of malathion by chloramines using deionized water and pH range from 3.0 to 9.0 (Duirk et al., 2010). The initial malathion concentration was $0.5 \mu\text{M}$ and the initial monochloramine dose was $50 \mu\text{M}$. Auto-decomposition of monochloramine is a pH-dependent process and allows for multiple chlorinated oxidants to coexist at neutral pH [i.e., monochloramine (NH_2Cl), dichloramine (NHCl_2) and HOCl] (Valentine and Jafvert, 1992). The reaction rate of monochloramine to degrade malathion was low. Dichloramine exhibited a reaction rate two orders of magnitude higher than monochloramine, but three orders of magnitude lower than hypochlorous acid. Of the three chloramines, monochloramine is the preferred species for use in disinfecting drinking water because of its biocidal properties, relative stability, and because it rarely causes taste and odour problems when compared with dichloramine and trichloramine (Health Canada, 2020c). The authors reported that a 56% degradation of malathion was due mostly to the oxidation by dichloramine, when oxidation was conducted at a pH of 6.5. Above pH 8.0, alkaline hydrolysis was the primary degradation pathway for malathion, achieving 93% degradation (Duirk et al., 2010).

Organophosphorus pesticides contain a phosphorous/sulphur bond ($\text{P}=\text{S}$) that is highly reactive and easily degraded by oxidation, producing oxons having phosphorous/oxygen ($\text{P}=\text{O}$) bonds as a primary degradation by-product (Magara et al., 1994; Kamel et al., 2009; Beduk et al., 2012). Malaoxon is more persistent than malathion and has a degradation kinetic lower than its parent molecule (Magara et al., 1992; Durik et al., 2010; Beduk et al., 2012; Li et al., 2019). Li et al. (2019) reported that ratios of degradation rate constant of malathion to degradation rate constant of malaoxon ($k_{\text{malathion}}/k_{\text{malaoxon}}$) ranged from 4.3 to 5.6 for several oxidation and AOPs reactions. The degradation rate constants of 6.5×10^4 and $1.4 \times 10^4 \text{ cm}^2 \text{ mJ}^{-1}$ were measured for malathion and malaoxon, respectively, in UV oxidation process; while for UV/ H_2O_2 oxidation (discussed in Section 4.1.2.5) the degradation rates were 133.6×10^4 and $23.9 \times 10^4 \text{ cm}^2 \text{ mJ}^{-1}$ for malathion and malaoxon, respectively. Additionally, a study conducted by Aizawa and Magara (1992) (as cited in Magara et al., 1994) reported that two other degradation by-products, ethyl chloromaleic acid and ethyl maleate, formed during chlorination of malathion. Newhart (2006) also reported on several degradation by-products resulting from hydrolysis of malathion in alkaline aerobic conditions such as malathion alpha and beta monoacids, diethyl fumarate, diethyl thiomalate, O,O-dimethylphosphorodithioic acid, diethylthiomalate and O,O-dimethylphosphorothionic acid. No treatment information was provided in the study.

Beduk et al. (2012) investigated malathion degradation by ozonation and the formation of malaoxon. While the malathion concentration of $200 \mu\text{g/L}$ was completely removed, malaoxon at a concentration of $12 \mu\text{g/L}$ was formed at an ozone dose of 1.5 mg/L and pH 9.5. Increasing the ozone dose to 2 and 2.5 mg/L caused the malaoxon formation to drop to

8 and 7 µg/L, respectively. The authors concluded that even high ozone doses were not efficient for complete removal of malaoxon. Duirk et al. (2010) reported that malaoxon was highly stable in the presence of chloramine at a pH of 8.5.

TABLE 10: Removal of malathion via oxidation

Oxidant	Influent (µg/L)	Oxidant Dose (mg/L, unless indicated otherwise)	Removal (%) or Reaction Rate (M ⁻¹ H ⁻¹)	Process Description	Reference
Cl ₂	1.5–3	2–5	> 50% (pHs 6.6 and 8.6)	Bench-scale: buffered water (sodium phosphate); 23 ± 1°C and pHs of 6.6 and 8.6	Chamberlain et al. (2012)
O ₃		1–2	> 50% (pH 6.6) 20%–50% (pH 8.6)		
NH ₂ Cl		9–14	< 20%		
MnO ₄ ⁻		3–5			
ClO ₂		2–3			
H ₂ O ₂		100			
UV ₂₅₄		77–97 mWs/cm ²			
UV ₂₅₄	200	-	4.4%	Bench-scale reactor: deionized water; medium pressure UV lamp; 90 min contact time	Beduk et al. (2012)
O ₃	11.0	1	70.9%	Bench-scale: dechlorinated tap water spiked with pesticides; TOC = 2.1 mg/L; alkalinity = 240 mg/L CaCO ₃ ; pH 8.3; ozone demand = 0.5 mg/L; cont. time of 10 min;	Roche and Prados (1995)
		2	89.1%		
		3	96.5%		
		4	> 99%		
		5	> 99%		
	200	1.5	~ 100% in: 20 min (pH 9.0); 30 min (pHs 6.5)	Bench-scale reactor: deionized water; pHs of 6.5 and 9.0. Malaoxon formation	Beduk et al. (2012)
HOCl/OCl ⁻	0.5 µM (165.2 µg/L)	0–100 µM	1.72 (± 0.36) × 10 ⁶ / 382 (± 0.26) M ⁻¹ H ⁻¹	Bench scale: deionized water; 0.5 µM malathion, pH 6.5, T° 25 ± 1°C	Duirk et al. (2009)

TOC: total organic carbon.



4.2.1.5 Advanced Oxidation Processes

AOPs use chemical reactions to form hydroxyl radicals that are used to oxidize chemical compounds, such as pesticides (Crittenden et al., 2012). Several different advanced oxidation processes have been investigated for malathion degradation, including UV/hydrogen peroxide (H_2O_2); O_3 /UV and O_3 / H_2O_2 /UV (see Table II).

In laboratory tests, the presence of carbonate and sulphate ions was found to negatively impact the degradation of malathion when UV/ H_2O_2 was used, with carbonate having the most impact (Fadaei, et al., 2012). The authors reported that malathion degradation was highest in distilled water, followed by tap water and then river water. This observed difference in malathion degradation was due to hydroxyl scavenger property of bicarbonate and sulphate ions and the presence of organic carbon in natural waters. An increase of pH and hydrogen peroxide concentration increased the degradation rate for malathion.

Beduk et al. (2012) investigated the degradation of malathion and subsequent formation of malaoxon in aqueous solution using photocatalytic ozonation (O_3 /UV and O_3 //UV/ H_2O_2). Efficient removal of both malathion and the formed malaoxon was found for O_3 / H_2O_2 /UV after 10- and 30-minutes' reaction time, respectively.

A bench-scale study by Roche and Prados (1995) achieved a greater than 99% degradation of malathion for all applied doses of O_3 with H_2O_2 added at a constant ratio of 0.4 g H_2O_2 /g O_3 . The results in Table II indicate that approximately 100% degradation of malathion was achieved with 1.0 mg O_3 /L and an addition of 0.4 mg H_2O_2 /L, as compared to the process with ozone alone requiring 4.0 mg O_3 /L. A similar study by Li et al. (2019), showed a much higher reaction rate (two orders of magnitude) for UV/ H_2O_2 oxidation as compared to direct UV photolysis. The degradation reaction by direct UV photolysis involved a photon adsorption, while the UV/ H_2O_2 reaction involved formation of hydroxyl radical. Li et al. (2019) also evaluated the formation of by-products. The study reported that each AOP was found to form their own respective grouping of degradation by-products. Based on total organic carbon (TOC) analysis, low mineralization was achieved for malathion under the studied processes. Malathion was converted to degradation by-products rather than being mineralized to CO_2 and water.

Prior to full-scale application, appropriate pilot-scale or bench-scale testing would need to be conducted evaluating malathion removal as well as the degradation products.

TABLE II: Removal of malathion via advanced oxidation processes

Process	Infl. ($\mu\text{g/L}$ or μM)	Initial Oxidant Dose (mg/L) or UV power (W)	Catalyst	Removal (%) or Reaction Rate (cm^2/mJ)	Process Description and By-Product Information	Reference
UV/ H_2O_2	200, 400 and 600	150 W medium pressure mercury lamp	10 mg/L H_2O_2	Average removal: $77.88 \pm 23.96\%$	Distilled water: pHs 3.0, 7.0 and 9.0; $T = 25 \pm 1^\circ\text{C}$; contact time 180 sec	Fadaei et al. (2012)
			30 mg/L H_2O_2	Average removal: $82.17 \pm 24.24\%$		
			30 mg/L H_2O_2	~ 45% (in 60 sec) ~ 65% (in 180 sec)	Tap water spiked 200 $\mu\text{g/L}$ malathion; turbidity 1 NTU; pH 7.44; alkalinity 210 mg/L as CaCO_3 ; HCO_3^- 256 mg/L ; SO_4^{2-} 79 mg/L	
			30 mg/L H_2O_2	~ 40% (in 60 sec) ~ 60% (in 180 sec)	River water spiked 200 $\mu\text{g/L}$ malathion; turbidity 12.5 NTU; pH 7.46; alkalinity 290 mg/L CaCO_3 ; HCO_3^- 354 mg/L ; SO_4^{2-} 68 mg/L	
	15 μM	24 W with UV dose of 0.58 mW/cm^2	No H_2O_2	$6.5 \times 10^{-4} \text{cm}^2/\text{mJ}$	Bench-scale reactor: aqueous solution pH 7.0; $T = 20 \pm 0.5^\circ\text{C}$	
0.3 mM H_2O_2	$133.6 \times 10^{-4} \text{cm}^2/\text{mJ}$					
O_3/UV	200	2.0 mg/L O_3	UV 254 nm	~ 100% (in 12 min)	Bench-scale reactor: No complete degradation of malaaxon: 13 $\mu\text{g/L}$ in 10 min; 2 $\mu\text{g/L}$ after 90 min	Beduk et al. (2012)
$\text{O}_3/\text{UV}/\text{H}_2\text{O}_2$			UV 254 nm; H_2O_2 (20, 40 and 100 mg/L)	~ 100% (in 10 min)	Bench-scale reactor: Optimum: 40 mg/L H_2O_2 Malaaxon: 100% removal (in 30 min)	
$\text{O}_3/\text{H}_2\text{O}_2$	11.0	1, 2, 3, 4 and 5 mg/L O_3	0.4, 0.8, 1.2, 1.6 and 2.0 mg/L H_2O_2 ($\text{H}_2\text{O}_2/\text{O}_3 = 0.4 \text{g/g}$)	> 99% for all doses	Bench-scale: dechlorinated tap water spiked with pesticides; TOC = 2.1 mg/L ; alkalinity = 240 mg/L CaCO_3 ; pH 8.3; ozone demand = 0.5 mg/L ; ozone demand = 0.5 mg/L	Roche and Prados (1995)

TOC: total organic carbon.



4.2.1.6 Combined technologies

As discussed in the oxidation Section 4.2.1.4, formation of by-products such as malaoxon may occur through processes like chlorination. A bench-study by Li et al. (2016) investigated both the removal of malathion and the resulting formation of malaoxon. The authors illustrated that the removal efficiency by coagulation and a combination of coagulation and PAC was better for malathion (5% and 38%, respectively) than malaoxon (2% and 24%, respectively). The authors then examined the impacts of various pre-chlorination doses on overall malathion removal throughout the treatment process by investigating the gross removal of both malathion and malaoxon after the various stages. A treatment train consisting of pre-chlorination, PAC-assisted coagulation-sedimentation-filtration and post chlorination was used with varying doses of pre-chlorination (0 to 3 mg/L) (see Table 12). The best total gross removal of both malathion and malaoxon was for the scenario in which no pre-chlorination occurred. Without pre-chlorination, malathion was not oxidized to the less well-removed malaoxon, resulting in overall better gross removal. As the pre-chlorination dose increased, malaoxon formed, causing the overall removal to decline.

TABLE 12: Removal of malathion and malaoxon through PAC/coagulation (Li et al., 2016)

Influent (µg/L)	Pre-CCl dose (mg/L)	Gross Removal of Malathion and Malaoxon (%)				Process description
		Pre-Cl	PAC-CSF	Post-Cl	Total	
10	0	0.0	37.5	5.0	42.5	Bench-scale: Raw river water (pH 7.3; conductivity = 267 µS/cm; turbidity = 4.15 NTU; DOC = 4.37 mg/L; UV ₂₅₄ = 0.127 cm ⁻¹ ; Alkalinity=77.1 mg/L; Na ⁺ = 6.3 mg/L; K ⁺ = 2.2 mg/L; Ca ²⁺ = 48 mg/L; Mg ²⁺ = 4.6 mg/L; SO ₄ ²⁻ = 30.2 mg/L; Cl ⁻ = 18.6 mg/L; F ⁻ = 0.7 mg/L) 10 mg/L PAC; 120 µM Al ₂ SO ₄ Rapid mixing: 250 rpm for 1 minute; Slow mixing: 30 rpm for 15 min; Settling for 30 min; Post-chlorination 1 mg/L for 30 minutes.
	0.25	-0.2	32.0	7.4	39.2	
	0.5	1.0	27.7	7.1	35.8	
	0.75	2.5	23.3	7.4	33.2	
	1	-0.7	19.9	7.6	26.8	
	1.5	4.7	16.2	3.3	24.2	
	2	8.4	16.1	0.4	24.9	
	3	8.5	15.1	0.2	23.8	

DOC: dissolved organic carbon; PAC-CSF: powdered activated carbon assisted coagulation-sedimentation-filtration.

4.2.2 Residential-scale

In cases where malathion removal is desired at the household level, for example, when a household obtains its drinking water from a private well, a residential drinking water treatment unit may be an option for decreasing malathion concentrations in drinking water. Before a treatment unit is installed, the water should be tested to determine the general water chemistry and malathion concentration in the source water.

To verify that a treatment unit is effective, water entering and leaving the treatment unit should be sampled periodically and submitted to an accredited laboratory for analysis. Units can lose removal capacity through use and time and need to be maintained and/or replaced. Consumers should verify the expected longevity of the components in the treatment unit according to the manufacturer's recommendations and service it when required. Systems classified as residential scale may have a rated capacity to treat volumes greater than that needed for a single residence, and thus, may also be used in small systems.

Health Canada does not recommend specific brands of drinking water treatment units, but it strongly recommends that consumers use units that have been certified by an accredited certification body as meeting the appropriate NSF International Standard/American National Standard (NSF/ANSI) for drinking water treatment units. The purpose of these standards is to establish minimum requirements for the materials, design and construction of drinking water treatment units that can be tested by a third party. This ensures that materials in the unit do not leach contaminants into the drinking water (i.e., material safety). In addition, the standards include performance requirements that specify the removal that must be achieved for specific contaminants (e.g., reduction claim) that may be present in water supplies. Certification organizations (i.e., third party) provide assurance that a product conforms to applicable standards and must be accredited by the Standards Council of Canada. Accredited organizations in Canada include:

- » Groupe CSA (www.csagroup.org);
- » NSF International (www.nsf.org);
- » Water Quality Association (www.wqa.org);
- » UL LLC (www.ul.com);
- » Bureau de normalisation du Québec (www.bnq.qc.ca) (available in French only);
- » International Association of Plumbing and Mechanical Officials (www.iapmo.org); and
- » Truesdail Laboratories, Inc (www.truesdail.com).

An up-to-date list of accredited certification organizations can be obtained from the Standards Council of Canada (www.scc.ca).

The drinking water treatment technologies that are expected to be effective for malathion removal at the residential-scale include adsorption and RO. Currently, malathion is not included in the performance requirements of NSF/ANSI standards. However, consumers can use a treatment unit that is certified to the standards for RO or adsorption to ensure that the material safety has been tested. These standards are NSF/ANSI Standard 53 Drinking Water Treatment Units – Health Effects and NSF/ANSI Standard 58 Reverse Osmosis Drinking Water Treatment Systems (NSF/ANSI, 2020 a, 2020b). In addition, systems



or units that have been certified for the removal of pesticides (e.g., atrazine) are more likely to be effective for the removal of malathion.

Water that has been treated using RO may be corrosive to internal plumbing components. Therefore, these units should be installed only at the point of use. As large quantities of influent water are needed to obtain the required volume of treated water, these units are generally not practical for point-of-entry installation.

5.0 MANAGEMENT STRATEGIES

All water utilities should implement a risk management approach, such as the source-to-tap or water safety plan approach, to ensure water safety (CCME, 2004; WHO, 2017b, 2012). These approaches require a system assessment to characterize the source water, describe the treatment barriers that prevent or reduce contamination, identify the conditions that can result in contamination and implement control measures. Operational monitoring is then established and operational/management protocols are instituted (e.g., standard operating procedures, corrective actions and incident responses). Compliance monitoring is determined and other protocols to validate the water safety plan are implemented (e.g., record keeping, consumer satisfaction). Operator training is also required to ensure the effectiveness of the water safety plan at all times (Smeets et al., 2009).

5.1 Monitoring

Malathion can be present in groundwater and surface water in areas where it is being used depending on the type and extent of its application, environmental factors (e.g., amount of precipitation, soil type, hydrogeological setting) and environmental fate (e.g., mobility, leaching potential, degradation) in the surrounding area. Water utilities should consider the potential for malathion to enter source water (e.g., raw water supply to the drinking water system) based on site-specific considerations.

When it is determined that malathion may be present and monitoring is necessary, then surface and groundwater sources should be characterized to determine the concentration of malathion. This should include monitoring of surface water sources during periods of peak use and rainfall events and/or monitoring of groundwater annually. Where baseline data indicate that malathion is not present in source water, monitoring may be reduced.

Where treatment is required to remove malathion, operational monitoring should be implemented to confirm whether the treatment process is functioning as required. The frequency of operational monitoring will depend on the water quality, fluctuations of the raw water concentrations and the treatment process. Responsible authorities should be aware of the impact of natural organic matter on activated carbon systems, as it may impact water quality objectives for malathion removal.

Where treatment is in place for malathion removal, compliance monitoring (i.e., paired samples of source and treated water to confirm the efficacy of treatment) should be conducted at a minimum on an annual basis. When routine operational monitoring indicates the potential for contaminant breakthrough, such as with GAC, monitoring should be conducted at least quarterly to plan for change-out of media. When a degradation process, like oxidation, is utilized, monitoring of by-product formation should also be considered.

6.0 INTERNATIONAL CONSIDERATIONS

Other national and international organizations have drinking water guidelines, standards and/or guidance values for malathion in drinking water. Variations in these values can be attributed to the age of the assessments or to differing policies and approaches, including the choice of key study and the use of different consumption rates, body weights and source allocation factors (Table 13).

The Australian National Health and Medical Research Council (NHMRC) has set a guideline value of 0.07 mg/L for malathion in drinking water based on erythrocyte ChE inhibition in rats (NHMRC and NRMCC, 2011). The U.S. EPA does not have a maximum contaminant level (MCL) for malathion (U.S. EPA, 2009). The World Health Organization (WHO) concluded that malathion occurs in drinking water at levels well below those of health concern and therefore has not established a formal guideline value for malathion (WHO, 2004, 2017b).

The European Union (EU) does not have a specific chemical parametric value for individual pesticides. Instead, the EU has a value of 0.1 µg/L for any individual (single) pesticide, and a value of 0.5 µg/L for total pesticides found in drinking water. In establishing these values, the EU did not consider the science related to each pesticide, such as health effects. Instead, the values are based on a policy decision to keep pesticides out of drinking water (EU, 1998).



TABLE 13: Comparison of international drinking water values for malathion

Agency (Year)	Value (mg/L)	Key Endpoint (Reference)	NO(A)EL (mg/kg bw per day)	UF	ADI (mg/kg bw/day)	bw (kg)	DW Intake (L/day)	AF (%)	Comments
Health Canada - MAC (2020)	0.29	Increase in severity of chronic kidney disease in a 2-year toxicity and carcinogenicity study in rats (Daly, 1996)	3 (NOAEL)	100	0.030	74	1.53	20	
U.S. EPA (2009; 2018)	0.5 (non-regulatory lifetime health advisory)	Erythrocyte ChE inhibition in offspring from the comparative ChE multiple dose oral study in rats (U.S. EPA, 2009)	7.1 (BMDL ₁₀)	100	0.07 (RfD)	70	2	20	U.S. EPA has set a non-regulatory lifetime health advisory rather than a MCL for malathion in drinking water, which is calculated from its associated Drinking Water Equivalent Level (DWEL) of 2 mg/L, obtained from its RfD (U.S. EPA, 2018).
WHO (2004; 2017b)	0.9 (non-regulatory HBV)	Decreased survival, reduced body weight and decreased ChE activity in a 2-year toxicity and carcinogenicity study in rats (Daly, 1996).	29 (NOAEL)	100	0.3	60	2	10	WHO has set a non-regulatory HBV rather than a formal guideline for malathion in drinking water (WHO, 2017b).

Agency (Year)	Value (mg/L)	Key Endpoint (Reference)	NO(A)EL (mg/kg bw per day)	UF	ADI (mg/kg bw/day)	bw (kg)	DW Intake (L/day)	AF (%)	Comments
Australia (NHMRC and NRMCC, 2011)	0.07	Erythrocyte ChE inhibition in two-year rat study (Daly, 1996)	2 (NOEL)	100	0.02	70	2	10	No reference for the two-year rat study is provided in NHMRC and NRMCC (2011) although description is consistent with Daly (1996).
EU (2020)	0.1 µg/L	The EU has a value of 0.1 µg/L for any individual (single) pesticide, and a value of 0.5 µg/L for total pesticides found in drinking water. In establishing these values, the EU did not consider the science related to each pesticide, including health effects. Instead, the values are based on a policy decision to keep pesticides out of drinking water.							

AF: allocation factor; BMDL₁₀: benchmark dose lower confidence limit associated with a 10% response; bw: body weight; ChE: cholinesterase; DW: drinking water; DWEL: drinking water equivalent level; EU: European Union; HBV: health based value; MAC: maximum acceptable concentration; MCL: maximum contaminant level; NO(A)EL: no observed (adverse) effect level; RfD: reference dose; UF: uncertainty factor;

7.0 RATIONALE

Malathion is a registered insecticide and acaricide used on a wide variety of sites including agricultural and non-agricultural sites. Despite its common use in Canada, data provided by provinces and territories that monitor for malathion in source and drinking water indicate that, when detected, levels of malathion are well below the MAC. The kidney has been identified as the most sensitive target organ for malathion toxicity. Although no human studies have investigated the effects of malathion on the kidney, animal studies conducted in rats and dogs have consistently shown nephrotoxicity following malathion exposure. Malathion also inhibits ChE but at higher doses than those causing nephrotoxicity. Its active metabolite, malaoxon, has been shown to be a more potent ChE inhibitor. Malaoxon is only a minor environmental degradate of malathion but can be produced during drinking water treatment. Nevertheless, because reported levels of malathion in source and drinking water are well below the MAC, any formation of malaoxon during water treatment is expected to be negligible. Therefore, this document does not propose an additive approach (i.e., use of a TAF) for malathion and malaoxon in drinking water. An additive approach for malathion and malaoxon in drinking water would result in added monitoring requirements and costs, with no improvement in health protection.



Health Canada, in collaboration with the Federal-Provincial-Territorial Committee on Drinking Water established a MAC of 0.29 mg/L (290 µg/L) for malathion in drinking water based on the following considerations:

- » An HBV of 0.29 mg/L (290 µg/L) based on an increase in severity of chronic nephropathy in female rats.
- » Analytical methods are available to accurately measure malathion at concentrations well below the MAC.
- » Treatment technologies are available to effectively decrease malathion at concentrations well below the MAC.

The MAC is protective of potential health effects from malathion exposure. As part of its ongoing guideline review process, Health Canada will continue to monitor new research in this area, including the outcomes of PMRA's evaluations, and recommend any change to this guideline technical document that it deems necessary.

8.0 REFERENCES

AGAT Laboratories Ltd. (2019). Personal communication with N. Boulton. Waterloo, ON.

Ahmed, T., Pathak, R., Mustafa, M.D., Kar, R., Tripathi, A.K., Ahmed, R.S. and Banerjee, B.D. (2011). Ameliorating effect of N-acetylcysteine and curcumin on pesticide-induced oxidative DNA damage in human peripheral blood mononuclear cells. *Environ. Monit. Assess.*, 179: 293–299.

Aizawa, T. and Magara, Y. (1992). Behavior of pesticides in drinking water purification system. Water Malaysia. '92, 8th. Aspac-IWSA regional water supply conference and exhibition. Technical paper 3 10D2-1-10D2-9.

Akbel, E., Arslan-Acaroz, D., Demirel, H.H., Kucukkurt, I. and Ince, S. (2018). The subchronic exposure to malathion, an organophosphate pesticide, causes lipid peroxidation, oxidative stress, and tissue damage in rats: the protective role of resveratrol. *Toxicol. Res.*, 7: 503–512.

Akhgari, M., Abdollahi, M., Kebryaezadeh, A., Hosseini, R. and Sabzevari, O. (2003). Biochemical evidence for free radical-induced lipid peroxidation as a mechanism for subchronic toxicity of malathion in blood and liver of rats. *Hum. Exp. Toxicol.*, 22(4): 205–211.

Alavanja, M.C., Hofmann, J.N., Lynch, C.F., Hines, C.J., Barry, K.H., Barker, J., Buckman, D.W., Thomas, K., Sandler, D.P., Hoppin, J.A., Koutros, S., Andreotti, G., Lubin, J.H., Blair, A. and Beane Freeman, L.E. (2014). Non-Hodgkin lymphoma risk and insecticide, fungicide and fumigant use in the Agricultural Health Study. *PLoS One*, 9(10): e109332.

Albright, R.K., Kram, B.W. and White, R.P. (1983). Malathion exposure associated with acute renal failure. *JAMA*, 250(18): 2469.

Alp, H., Aytakin, I., Esen, H., Alp, A., Buyukbas, S., Basarali, K., Hatipoglu, N.K. and Kul, S. (2011). Protective effects of caffeic acid phenethyl ester, ellagic acid, sulforaphan and curcuma on malathion induced damage in lungs, liver and kidneys in an acute toxicity rat model. *Revue Méd. Vét.*, 162(7): 333–340.

ALS Environmental (2019). Personal communication with A. Ganouri-Lumsden. Waterloo, ON.

Andreotti, G., Freeman, L.E., Hou, L., Coble, J., Rusiecki, J., Hoppin, J.A., Silverman, D.T. and Alavanja, M.C. (2009). Agricultural pesticide use and pancreatic cancer risk in the Agricultural Health Study Cohort. *Int. J. Cancer*, 124(10): 2495–500.

Aston, L.S. (2000). Determination of residues of malathion dicarboxylic acid (DCA), malathion monocarboxylic acid (MCA), dimethyl phosphate (DMP), dimethyl thiophosphate (DMTP), and dimethyl dithiophosphate (DMDTP) in human urine. Unpublished study prepared by Pacific Toxicology Laboratories. California, USA. (as cited in U.S EPA, 2016; WHO, 2017a)

ATSDR (2003). Toxicological profile for malathion. Agency for Toxic Substances and Disease Registry, United States Department of Health and Human Services, Public Health Service, Atlanta, Georgia.

Band, P.R., Abanto, Z., Bert, J., Lang, B., Fang, R., Gallagher, R.P. and Le, N.D. (2011). Prostate cancer risk and exposure to pesticides in British Columbia farmers. *Prostate*, 71(2): 168–183.

Barnett Jr., J.F. (2012a). Oral (diet) repeated dose 28-day toxicity study of malathion technical in rats. Study no. TQC00065 by Charles River Laboratories Preclinical Services. Unpublished report, Cheminova A/S, CHA Doc. No.: 1108 FYF. (as cited in WHO, 2017a)

Barnett Jr., J.F. (2012b). Oral (diet) repeated dose 90-day toxicity study of malathion technical in rats. Study no. TWC00066 by Charles River Laboratories Preclinical Services. Unpublished report, Cheminova A/S, CHA Doc. No.: 1096 FYF. Submitted to WHO by FMC/Cheminova. (as cited in WHO, 2017a)

Beduk, F., Aydin, M. E. and Ozcan, S. (2012). Degradation of malathion and parathion by ozonation, photolytic ozonation, and heterogeneous catalytic ozonation processes. *Clean (Weinh)*, 40 (2): 179–87.

Bellona, C., Drewes, J.E., Xu, P. and Amy, G. (2004). Factors affecting the rejection of organic solutes during NF/RO treatment – a literature review. *Water Res.*, 38: 279502809.

Blasiak, J., Jaloszynski, P., Trzeciak, A. and Szyfter, K. (1999). In vitro studies on the genotoxicity of the organophosphorus insecticide malathion and its two analogues. *Mutat. Res.*, 445(2): 275–283.

British Columbia Ministry of Health (2019). Personal communication with D. Fishwick.

Buratti, F.M. and Testai, E. (2005). Malathion detoxification by human hepatic carboxylesterases and its inhibition by isomalathion and other pesticides. *J. Biochem. Mol. Toxicol.*, 19(6): 406–414.

CARO Analytical Services (2019). Personal communication with K. Fyffe.

CCME (2004). From source to tap: Guidance on the multi-barrier approach to safe drinking water. Canadian Council of Ministers of the Environment, Winnipeg, Manitoba.

CFIA (2019a). 2015/16 Annual report: National Chemical Residue Monitoring Program and Chemistry Food Safety Oversight Program. Canadian Food Inspection Agency, Ottawa, Ontario.

CFIA (2019b). Children's Food Project - final report 2014 to 2015. Canadian Food Inspection Agency, Ottawa, Canada.

Chamberlain, E., Shi, H., Wang, T., Ma, Y., Fulmer, A. and Adams, C. (2012). Comprehensive screening study of pesticide degradation via oxidation and hydrolysis. *J. Agr. Food Chem.*, 60 (1): 354–63.

Chen, H.H., Hsueh, J.L., Sirianni, S.R. and Huang, C.C. (1981). Induction of sister-chromatid exchanges and cell cycle delay in cultured mammalian cells treated with eight organophosphorus pesticides. *Mutat. Res.*, 88(3): 307–16.



- Chian, E.S.K., Bruce, W.N. and Fang, H.H.P. (1975). Removal of pesticides by reverse osmosis. *Environ. Sci. Technol.*, 9(1): 52–59.
- Chowdhury, Z.K., Summers, R.S., Westerhoff, G.P., Leto, B.J., Nowack, K.O. and Corwin, C.J. (2013). Activated carbon: Solutions for improving water quality. Passantino, L. B. (ed.). American Water Works Association. Denver, Colorado.
- Costa, R.O., Barcellos, P.S. and Canela, M.C. (2018). Removal of pesticide residues after simulated water treatment: byproducts and acetylcholinesterase inhibition. *Eletica Quim. J.*, 43(2): 65–73.
- Crittenden, J.C., Rhodes Truissell, R., Hand, D.W., Howe, K.J. and Tchobanoglous, G. (2012). *MWH's Water Treatment Principles and Design*, 3rd Edition. John Wiley & Sons, Inc. 1901pp.
- Daly, I.W. (1993a). A 28-day study of malathion in the rat via dietary administration. Study no. 92-3806 by Bio/Dynamics Inc. Unpublished report. Cheminova A/S, CHA Doc. No.: 68 FYF. (as cited in WHO, 2017a)
- Daly, I.W. (1993b). A subchronic (3-month) oral toxicity study of malathion in the rat via dietary administration. Study no. 92-3843 by Bio/Dynamics Inc. Unpublished report. Cheminova A/S, CHA Doc. No.: 70 FYF. (as cited in WHO, 2017a)
- Daly, I.W. (1996). A 24-month oral toxicity/oncogenicity study of malathion in the rat via dietary administration. Huntingdon Life Sciences, East Millstone, NJ. Study No. 90-3641, MRID 43942901, Unpublished. (as cited in U.S. EPA, 1997; Health Canada, 2010)
- Decker, U., Knuppe, C. and Ulrich, A. (2003). Malathion technical (fortified): 4-hour acute inhalation toxicity study in rats. RCC Ltd report 846761. Cheminova report No. 443 FYF. No summary or report. Unpublished. (as cited in FAO, 2004)
- De Roos, A.J., Zahm, S.H., Cantor, K.P., Weisenburger, D.D., Holmes, F.F., Burmeister, L.F. and Blair, A. (2003). Integrative assessment of multiple pesticides as risk factors for non-Hodgkin's lymphoma among men. *Occup. Environ. Med.*, 60(9): E11.
- Duirk, S. E., Desetto, L. M. and Davis, G. M. (2009). Transformation of organophosphorus pesticides in the presence of aqueous chlorine: Kinetics, pathways, and structure – activity relationships. *Environ. Sci. Technol.*, 43(7): 2335–40.
- Duirk, S. E., Desetto, L. M., Davis, G. M., Lindell, C. and Cornelison, C. T. (2010). Chloramination of organophosphorus pesticides found in drinking water sources. *Water Res.*, 44(3): 761–8.
- Dulout, F.N., Pastori, M.C. and Olivero, O.A. (1983). Malathion-induced chromosomal aberrations in bone-marrow cells of mice: dose-response relationships. *Mutat. Res.*, 122(2): 163–167.
- EFSA (2006). Conclusions regarding the peer review of the pesticide risk assessment of the active substance – malathion. EFSA Scientific Report, 63: 1–87. Available at <https://efsa.onlinelibrary.wiley.com/doi/epdf/10.2903/j.efsa.2006.63r>
- EFSA (2009). Conclusion on pesticide peer review regarding the risk assessment of the active substance malathion. EFSA Scientific Report, 333: 1–118.
- Element Materials Technology Canada Inc. (2019). Personal communication with H. Du.
- Engel, L. S., Hill, D. A., Hoppin, J. A., Lubin, J. H., Lynch, C. F., Pierce, J., Samanic, C., Sandler, D. P., Blair, A., and Alavanja, M. C. (2005). Pesticide use and breast cancer risk among farmers' wives in the Agricultural Health Study. *Am. J. Epidemiol.*, 161(2): 121–135.

Environment Canada (2011). Presence and Levels of Priority Pesticides in Selected Canadian Aquatic Ecosystems. Water Science and Technology Directorate. Cat. No.: En14-40/2011E-PDF.

EU (2020). Council Directive 2020/2184 of the European Parliament and of the Council of 16 December 2020 on the quality of water intended for human consumption (recast).

Fadaei, A.M., Dehghani, M.H., Mahvi, A.H., Nasser, S., Pastkari, N. and Shayeghi, M. (2012). Degradation of organophosphorus pesticides in water during UV/H₂O₂ treatment: Role of sulphate and bicarbonate ions. *E-J Chem.*, 9(4): 2015–2022.

FAO/WHO (1997). Pesticide residues in food 1997. Evaluations 1997. Part II - Toxicological and Environmental. Malathion, 189–219. IPCS, WHO/PCS/98.6.

FAO (2004). FAO specifications and evaluations for agricultural pesticides: Malathion: S-1,2-bis(ethoxycarbonyl) ethyl O,O-dimethyl phosphorodithioate. Food and Agriculture Organisation of the United States. Available at www.fao.org/fileadmin/templates/agphome/documents/Pests_Pesticides/Specs/Malathion2004.pdf

FAO/WHO (2016). Pesticides residues in food 2016. Report of the special session of the joint meeting of the FAO panel of experts on pesticide residues in food and the environment and the WHO core assessment group on pesticide residues, Geneva, Switzerland.

FIFRA (2000). A Set of Scientific Issues Being Considered by the Environmental Protection Agency regarding: A Consultation on the EPA Health Effect Division's Proposed Classification of the Human Carcinogenic Potential of Malathion. FIFRA Scientific Advisory Panel, SAP Report No. 2000-04. Meeting August 17-18, 2000, Arlington, VA.

Flower, K.B., Hoppin, J.A., Lynch, C.F., Blair, A., Knott, C., Shore, D.L. and Sandler, D.P. (2004). Cancer risk and parental pesticide application in children of agricultural health study participants. *Environ. Health Perspect.*, 112(5): 631–635.

Gervais, J.A., Luukinen, B., Buhl, K. and Stone, D. (2009). Malathion technical fact sheet. National Pesticides Information Centre, Oregon State University Extension Services.

Gillies, D. and Dickson, J. (2000). A randomized double blind ascending single oral dose study with malathion to determine the no effect level on plasma and RBC cholinesterase activity (3 volumes). Unpublished study by Inveresk Research. Tranent, Scotland. (as cited in U.S. EPA, 2016; WHO, 2017a)

Giri, S., Prasad, S.B., Giri, A. and Sharma, G.D. (2002). Genotoxic effects of malathion: An organophosphorus insecticide, using three mammalian bioassays in vivo. *Mutat. Res.*, 514(1–2): 223–231.

Giroux, I. (2016). Portrait de la présence de pesticides dans l'eau souterraine près de secteurs maraîchers, vergers, vignes et petits fruits – échantillonnage 2012 à 2014. Direction générale du suivi de l'état de l'environnement, ministère de l'Environnement et de la Lutte contre les changements climatiques, Gouvernement du Québec. Available at www.environnement.gouv.qc.ca/eau/flrivlac/pesticides.htm

Giroux, I. (2017). Présence de pesticides dans l'eau de surface au Québec- Zones de vergers et de cultures maraîchères, 2013 à 2016. Direction de l'information sur les milieux aquatiques, ministère de l'Environnement et de la Lutte contre les changements climatiques, Gouvernement du Québec. Available at www.environnement.gouv.qc.ca/eau/flrivlac/pesticides.htm

Giroux, I. (2019). Présence de pesticides dans l'eau au Québec : Portrait et tendances dans les zones de maïs et de soya – 2015 à 2017. Direction générale du suivi de l'état de l'environnement, ministère de l'Environnement et de la Lutte contre les changements climatiques, Gouvernement du Québec. Available at www.environnement.gouv.qc.ca/eau/flrivlac/pesticides.htm



- Goldner, W.S., Sandler, D.P., Yu, F., Hoppin, J.A., Kamel, F. and Levan, T.D. (2010). Pesticide use and thyroid disease among women in the Agricultural Health Study. *Am. J. Epidemiol.*, 171(4): 455–464.
- Goldner, W.S., Sandler, D.P., Yu, F., Shostrom, V., Hoppin, J.A., Kamel, F. and LeVan, T.D. (2013). Hypothyroidism and pesticide use among male private pesticide applicators in the Agricultural Health Study. *J. Occup. Environ. Med.*, 55(10): 1171–1178.
- Gustafson, D.K., Carr, K.H., Carson, D.B., Fuhrman, J.D., Hackett, A.G., Hoogheem, T.J., Snoeyink, V.L., Curry, M., Heijman, B., Chen, S., Herti, P. and van Wesenbeeck, I. (2003). Activated carbon adsorption of chloroacetanilide herbicides and their degradation products from surface water supplies. *J. Water Supply Res. Technol. AQUA*, 52(6): 443–454.
- Haist-Gulde, B. and Happel, O. (2012). Removal of pesticides and their ionic degradates by adsorptive processes. Report no. 4022. Water Research Foundation, Denver, Colorado.
- Health Canada (2003). Proposed acceptability for continuing registration. PACR2003–10. Re-evaluation of malathion. Pest Management Regulatory Agency (PMRA), Health Canada, Ottawa, Canada
- Health Canada (2010). Proposed re-evaluation decision. PRVD2010–18. Malathion. Pest Management Regulatory Agency (PMRA), Health Canada, Ottawa, Canada.
- Health Canada (2012). Re-evaluation decision. RVD2012–10. Malathion. Pest Management Regulatory Agency (PMRA), Health Canada, Ottawa, Canada.
- Health Canada (2015). Carcinogenicity classification of five pesticides by the International Agency for Research on Cancer (IARC) March 2015. Fact Sheet. Pest Management Regulatory Agency (PMRA), Health Canada, Ottawa, Canada. Available at <https://www.canada.ca/en/health-canada/services/consumer-product-safety/reports-publications/pesticides-pest-management/fact-sheets-other-resources/carcinogenicity-classification-five-pesticides-international-agency-research-cancer-iarc-march-2015.html>
- Health Canada (2019a). Personal Communication with the Health Evaluation Directorate, Pest Management Regulatory Agency (PMRA).
- Health Canada (2019b). Fifth Report on Human Biomonitoring of Environmental Chemicals in Canada: Results of the Canadian Health Measures Survey Cycle 5 (2016–2017). Minister of Health, Ottawa, Canada.
- Health Canada (2020a). Pest control products sales report for 2018. Pest Management Regulatory Agency (PMRA), Health Canada, Ottawa, Canada.
- Health Canada (2020b). Maximum Residue Limits (MRL) for pesticides database: malathion. Health Canada, Consumer Product Safety, Pesticides and Pest Management. Available at <https://pr-rp.hc-sc.gc.ca/mrl-lrm/index-eng.php>
- Health Canada (2020c). Guidelines for Canadian drinking water quality. Guideline technical document-Chloramines. Available at https://www.canada.ca/en/health-canada/services/environmental-workplace-health/reports-publications/water-quality.html#tech_doc
- Health Canada (2021a). Personal Communication with the Health Evaluation Directorate, Pest Management Regulatory Agency (PMRA).
- Health Canada (2021b). Canadian exposure factors used in human health risk assessments. Fact Sheet. Health Canada, Ottawa, Ontario. Available at <https://www.canada.ca/en/health-canada/services/chemical-substances/fact-sheets/canadian-exposure-factors-human-health-risk-assessments.html>

Hoppin, J.A., Umbach, D.M., London, S.J., Alavanja, M.C. and Sandler, D.P. (2002). Chemical predictors of wheeze among farmer pesticide applicators in the Agricultural Health Study. *Am. J. Respir. Crit. Care Med.*, 165(5): 683–689.

Hoppin, J.A., Umbach, D.M., London, S.J., Lynch, C.F., Alavanja, M.C. and Sandler, D.P. (2006). Pesticides and adult respiratory outcomes in the Agricultural Health Study. *Ann. N. Y. Acad. Sci.*, 1076: 343–354.

Hoppin, J.A., Umbach, D.M., London, S.J., Henneberger, P.K., Kullman, G.J., Alavanja, M.C. and Sandler, D.P. (2008). Pesticides and atopic and nonatopic asthma among farm women in the Agricultural Health Study. *Am. J.*

Respir. Crit. Care Med., 177(1): 11–18.

Hoppin, J.A., Umbach, D.M., London, S.J., Henneberger, P.K., Kullman, G.J., Coble, J., Alavanja, M.C., Beane Freeman, L.E. and Sandler, D.P. (2009). Pesticide use and adult-onset asthma among male farmers in the Agricultural Health Study. *Eur. Respir. J.*, 34(6): 1296–1303.

IARC (2017). IARC monographs on the evaluation of carcinogenic risks to humans: Some organophosphate insecticides and herbicides. Volume 112. Working Group on the Evaluation of Carcinogenic Risks to Humans. International Agency for Research on Cancer, World Health Organization, Lyon, France. Available at <https://publications.iarc.fr/549>

Ikehata, K. and Gamal El-Din, M. (2006). Aqueous pesticide degradation by hydrogen peroxide/ultraviolet irradiation and Fenton-type oxidation processes: A review. *J. Environ. Eng. Sci.*, 5(2): 81–135.

Indigenous Services Canada (2019). Personal communication with X. Redhead.

Jellinek, Schwartz & Connolly Inc (2000). The effects and pharmacological disposition of a single oral dose of malathion administered to human volunteers. Unpublished study sponsored and submitted by Cheminova Agro A/S. (as cited in WHO, 2017a)

Jensen, I.M. and Whatling, P. (2010). Chapter 71- malathion: A review of toxicology. In: Hayes' handbook of pesticide toxicology. Krieger, R. (ed.). 3rd edition. pp. 1527–1542.

Jokanovic, M. (2018). Neurotoxic effects of organophosphorus pesticides and possible association with neurodegenerative diseases in man: A review. *Toxicology*, 410(2018): 125–131.

Jusoh, A., Lam, S.S., Hartini, W.J.H. and Ali, N. (2014). Removal of pesticide in agricultural runoff using granular-activated carbon: A simulation study using a fixed-bed column approach. *Desalin. Water Treat.*, 52(4–6): 861–866.

Kamel, F., Tanner, C., Umbach, D., Hoppin, J., Alavanja, M., Blair, A., Comyns, K., Goldman, S., Korell, M., Langston, J., Ross, G. and Sandler, D. (2007). Pesticide exposure and self-reported Parkinson's disease in the agricultural health study. *Am. J. Epidemiol.*, 165(4): 364–374.

Kamel, A., Byrne, C., Vigo, C., Ferrario, J., Stafford, C., Verdin, G., Siegelman, F., Knizner, S. and Hetrick, J. (2009). Oxidation of selected organophosphate pesticides during chlorination of simulated drinking water. *Water Res.*, 43(2): 522–534.

Kiso, Y., Nishimura, Y., Kitao, T. and Nishimura, K. (2000). Rejection properties of non-phenylic pesticides with nanofiltration membranes. *J. Membr. Sci.*, 171(2): 229–237.

Knappe, D.R.U., Snoeyink, V.L., Roche, P., Prados, M.J. and Bourbigot, M-M. (1999). Atrazine removal by preloaded GAC. *J. Am. Water Works Assoc.*, 91(10): 97–109.



- Koutros, S., Beane Freeman, L.E., Lubin, J.H., Heltshe, S.L., Andreotti, G., Barry, K.H., DellaValle, C.T., Hoppin, J.A., Sandler, D.P., Lynch, C.F., Blair, A. and Alavanja, M.C. (2013). Risk of total and aggressive prostate cancer and pesticide use in the Agricultural Health Study. *Am. J. Epidemiol.*, 177(1): 59–74.
- Koutros, S., Harris, S.A., Spinelli, J.J., Blair, A., McLaughlin, J.R., Zahm, S.H., Kim, S., Albert, P.S., Kachuri, L., Pahwa, M., Cantor, K.P., Weisenburger, D.D., Pahwa, P., Pardo, L.A., Dosman, J.A., Demers, P.A. and Beane Freeman, L.E. (2019). Non-Hodgkin lymphoma risk and organophosphate and carbamate insecticide use in the North American pooled project. *Environ. Int.*, 127: 199–205.
- Krstic, D.Z., Colovic, M., Bavcon kralj, M., Franco, M., Krinulovic, K., Trebse, P. and Vasic, V. (2008). Inhibition of AChE by malathion and some structurally similar compounds. *J. Enzyme Inhib. Med. Chem.*, 23(4): 562–573.
- Kumar, S.S., Ghosh, P., Malyan, S.K., Sharma, J. and Kumar, V. (2019). A comprehensive review on enzymatic degradation of the organophosphate pesticide malathion in the environment. *J. Environ. Sci. Health. C. Environ. Carcinog. Ecotoxicol. Rev., Part C*, 37: 1–42.
- Laveglia, J. and Dahm, P.A. (1977). Degradation of organophosphorus and carbamate insecticides in the soil and by soil microorganisms. *Annu. Rev. Entomol.*, 22: 483–513.
- Lee, W.J., Sandler, D.P., Blair, A., Samanic, C., Cross, A.J. and Alavanja, M.C. (2007). Pesticide use and colorectal cancer risk in the Agricultural Health Study. *Int. J. Cancer*, 121(2): 339–346.
- Leon, M.E., Schinasi, L.H., Lebailly, P., Beane Freeman, L.E., Nordby, K.C., Ferro, G., Monnereau, A., Brouwer, M., Tual, S., Baldi, I., Kjaerheim, K., Hofmann, J.N., Kristensen, P., Koutros, S., Straif, K., Kromhout, H. and Schuz, J. (2019). Pesticide use and risk of non-Hodgkin lymphoid malignancies in agricultural cohorts from France, Norway and the USA: A pooled analysis from the AGRICOH consortium. *Int. J. Epidemiol.*, 48(5): 1519–1535.
- Lerro, C.C., Koutros, S., Andreotti, G., Friesen, M.C., Alavanja, M.C., Blair, A., Hoppin, J.A., Sandler, D.P., Lubin, J.H., Ma, X., Zhang, Y. and Beane Freeman, L.E. (2015). Organophosphate insecticide use and cancer incidence among spouses of pesticide applicators in the agricultural health study. *Occup. Environ. Med.*, 72(10): 736–744.
- Li, W., Wu, R., Duan, J., Saint, C.P. and van Leeuwen, J. (2016). Impact of prechlorination on organophosphorus pesticides during drinking water treatment: Removal and transformation to toxic oxon byproducts. *Water Res.*, 105: 1–10.
- Li, W., Zhao, Y., Yan, X., Duan, J., Saint, C.P. and Beecham, S. (2019). Transformation pathway and toxicity assessment of malathion in aqueous solution during UV photolysis and photocatalysis. *Chemosphere*, 234: 204–214.
- Magara, Y., Aizawa, T., Matumoto, N. and Souna, F. (1994). Degradation of pesticides by chlorination during water purification. *Water Sci. Technol.*, 30 (7): 119–128.
- Manitoba Sustainable Development (2019). Personal communication with Dr. H.D. Coulibaly.
- Matsushita, T., Morimoto, A., Kuriyama, T., Matsumoto, E., Matsui, Y., Shirasaki, N., Kondo, T., Takanashi, H. and Kameya, T. (2018). Removals of pesticides and pesticide transformation products during drinking water treatment processes and their impact on mutagen formation potential after chlorination. *Water Res.*, 138: 67–76.
- McDuffie, H.H., Pahwa, P., McLaughlin, J.R., Spinelli, J.J., Fincham, S., Dosman, J.A., Robson, D., Skinnider, L.F. and Choi, N.W. (2001). Non-Hodgkin's lymphoma and specific pesticide exposures in men: Cross-Canada study of pesticides and health. *Cancer Epidemiol. Biomarkers Prev.*, 10(11): 1155–1163.

- Mills, P.K. and Yang, R. (2003). Prostate cancer risk in California farm workers. *J. Occup. Environ. Med.*, 45(3): 249–258.
- Mills, P.K. and Yang, R. (2005). Breast cancer risk in Hispanic agricultural workers in California. *Int. J. Occup. Environ. Health*, 11(2): 123–131.
- Mills, P.K., Dodge, J.L., Bush, J., Thompson, Y. and Shah, P. (2019). Agricultural exposures and breast cancer among Latina in the San Joaquin Valley of California. *J. Occup. Environ. Med.*, 61(7): 552–558.
- Miltner, R.J., Baker, D.B., Speth, T.F. and Fronk, C.A. (1989). Treatment of Seasonal Pesticides in Surface Waters. *J. Am. Water Works Assoc.*, 81, 43–52.
- Ministère de l'Environnement et de la Lutte contre les changements climatiques (2019). Personal communication with P. Cantin.
- Moeller, H.C. and Rider, J.A. (1962). Plasma and red blood cell cholinesterase activity as indications of the threshold of incipient toxicity of ethyl-p-nitrophenyl thionobenzenephosphonate (EPN) and malathion in human beings. *Toxicology and applied pharmacology. Toxicol. Appl. Pharmacol.*, 4(1): 123–130.
- Montgomery, M.P., Kamel, F., Saldana, T.M., Alavanja, M.C. and Sandler, D.P. (2008). Incident diabetes and pesticide exposure among licensed pesticide applicators: Agricultural health study, 1993–2003. *Am. J. Epidemiol.*, 167(10): 1235–1246.
- Moore, P.D., Yedjou, C.G. and Tchounwou, P.B. (2010). Malathion-induced oxidative stress, cytotoxicity, and genotoxicity in human liver carcinoma (HepG2) cells. *Environ. Toxicol.*, 25(3): 221–226.
- Naughton, S.X. and Terry Jr., A.V. (2018). Neurotoxicity in acute and repeated organophosphate exposure. *Toxicology*, 408: 101–112.
- NCI (1978). Bioassay of malathion for possible carcinogenicity. Technical report series no. 24. US Department of Health, Education and Welfare. Public Health Service. National Institute of Health. National Cancer Institute. (as cited in ATSDR, 2003)
- NCI (1979). Bioassay of malathion for possible carcinogenicity. National Cancer Institute. National Cancer Inst. Carcinog. Tech. Rep. Ser., Vol 192. (as cited in ATSDR, 2003)
- New Brunswick Department of Environment and Local Government (2019). Personal communication with K. Gould.
- Newfoundland and Labrador Department of Municipal Affairs and Environment (2019). Personal communication with H. Khan.
- Newhart, K.L. (2006). Environmental fate of malathion. California Environmental Protection Agency Department of Pesticide Regulation. Environmental Monitoring Branch.
- NHMRC and NRMCC (2011). Australian drinking water guidelines Paper 6 National Water Quality Management Strategy. National Health and Medical Research Council, National Resource Management Ministerial Council, Commonwealth of Australia, Canberra. Available at <https://www.Nhmrc.Gov.Au/about-us/Publications/Australian-Drinking-Water-Guidelines>
- Nishio, A. and Uyeki, E.M. (1981). Induction of sister chromatid exchanges in Chinese hamster ovary cells by organophosphate insecticides and their oxygen analogs. *J. Toxicol. Environ. Health*, 8(5–6): 939–946. (as cited in Health Canada, 2010; WHO, 2017a)



Nova Scotia Environment (2015). Nova Scotia Groundwater Observation Well Network: 2015 report. Available at <https://novascotia.ca/nse/groundwater/docs/GroundwaterObservationWellNetwork2015Report.pdf>

Nova Scotia Environment (2019). Personal communication with A. Polegato.

NSF/ANSI (2020a). Standard 53: Drinking water treatment units—health effects. NSF International/American National Standards Institute, Ann Arbor, Michigan.

NSF/ANSI (2020b). Standard 58: Reverse osmosis drinking water treatment systems. NSF International/American National Standards Institute, Ann Arbor, Michigan.

Ojha, A., Yaduvanshi, S.K., Pant, S.C., Lomash, V. and Srivastava, N. (2013). Evaluation of DNA damage and cytotoxicity induced by three commonly used organophosphate pesticides individually and in mixture, in rat tissues. *Environ. Toxicol.*, 28(10): 543–552.

Ojha, A. and Srivastava, N. (2014). In vitro studies on organophosphate pesticides induced oxidative DNA damage in rat lymphocytes. *Mutat. Res. Genet. Toxicol. Environ. Mutagen.*, 761: 10–17.

Ojha, A. and Gupta, Y.K. (2015). Evaluation of genotoxic potential of commonly used organophosphate pesticides in peripheral blood lymphocytes of rats. *Hum. Exp. Toxicol.*, 34(4): 390–400.

Olakkaran, S., Kizhakke Purayil, A., Antony, A., Mallikarjunaiah, S. and Hunasanahally Puttaswamygowda, G. (2020). Oxidative stress-mediated genotoxicity of malathion in human lymphocytes. *Mutation research - genetic toxicology and environmental mutagenesis. Mutat. Res. Genet. Toxicol. Environ. Mutagen.*, 849.

Ontario Ministry of the Environment, Conservation and Parks (2020). Personal communication with S. Deshpande.

PEI Department of Communities, Land and Environment (2019). Personal communication with G. Somers.

Plakas, K.V. and Karabelas, A.J (2012). Removal of pesticides from water by NF and RO membranes – a review. *Desalination*, 287:255–265.

Pluth, J.M., Nicklas, J.A., O'Neill, J.P. and Albertini, R.J. (1996). Increased frequency of specific genomic deletions resulting from in vitro malathion exposure. *Cancer Res.*, 56(10): 2393–2399.

Reddy, V., Freeman, T. and Cannon, M. (1989). Disposition and metabolism of ¹⁴C-labeled malathion in rats (preliminary and definitive study). Study no: 9354-B. Unpublished study prepared by Midwest Research Institute. Submitted by FMC/Cheminova. (as cited in Health Canada, 2010; WHO, 2017a)

Rinsky, J.L., Richardson, D.B., Kreiss, K., Nylander-French, L., Beane Freeman, L.E., London, S.J., Henneberger, P.K. and Hoppin, J.A. (2019). Animal production, insecticide use and self-reported symptoms and diagnoses of COPD, including chronic bronchitis, in the Agricultural Health Study. *Environ. Int.*, 127: 764–772.

Rocha, A.A., Monteiro, S.H., Andrade, G.C.R.M., Vilca, F.Z. and Tornisielo, V.L. (2015). Monitoring of pesticide residues in surface and subsurface waters, sediments, and fish in center-pivot irrigation areas. *J. Braz. Chem. Soc.*, 26(11): 2269–2278.

Roche, P. and Prados, M. (1995). Removal of pesticides by use of ozone or hydrogen Peroxide/Ozone. *Ozone-Sci. Eng.*, 17 (6): 657–672.

Saskatchewan Water Security Agency (2019). Personal communication with S. Ferris.

Sathiakumar, N., MacLennan, P.A., Mandel, J. and Delzell, E. (2011). A review of epidemiologic studies of triazine herbicides and cancer. *Crit. Rev. Toxicol.*, 41 Suppl 1: 1–34.

Selmi, S., Rtibi, K., Grami, D., Sebai, H. and Marzouki, L. (2018). Malathion, an organophosphate insecticide, provokes metabolic, histopathologic and molecular disorder in liver and kidney in prepubertal male mice. *Toxicol. Rep.*, 5: 189–195.

SGS Environmental Services (2019). Personal communication with D. Griffin. Lakefield, ON.

Shellenberger, T.E., Billups, L.H. (1987). One-year oral toxicity study in purebred beagle dogs with AC 6,601. Study no. 85010 by Tegeris Laboratories Inc. Unpublished report, Cheminova A/S, CHA Doc. No.: 9 FYF. (as cited in WHO, 2017a)

Shrestha, S., Parks, C.G., Goldner, W.S., Kamel, F., Umbach, D.M., Ward, M.H., Lerro, C.C., Koutros, S., Hofmann, J.N., Beane Freeman, L.E. and Sandler, D.P. (2018). Pesticide use and incident hypothyroidism in pesticide applicators in the Agricultural Health Study. *Environ. Health Perspect.*, 126(9): 97008.

Shrestha, S., Parks, C.G., Goldner, W.S., Kamel, F., Umbach, D.M., Ward, M.H., Lerro, C.C., Koutros, S., Hofmann, J.N., Beane Freeman, L.E. and Sandler, D.P. (2019). Pesticide use and incident hyperthyroidism in farmers in the Agricultural Health Study. *Occup. Environ. Med.*, 76(5): 332–335.

Singh, B., Kaur, J. and Singh, K. (2014). Microbial degradation of an organophosphate pesticide, malathion. *Crit. Rev. Microbiol.*, 40(2): 146–154.

Slauter, R.W. (1994). 18-month oral (dietary) oncogenicity study in mice, test substance malathion. Study no. 668-001 by International Research and Development Corp. Unpublished report, Cheminova A/S, CHA Doc. No.: 94 FYF. (as cited in WHO, 2017a)

Smeets, P.W.M.H., Medema, G.J. and van Dijk, J.C. (2009). The Dutch secret: how to provide safe drinking water without chlorine in the Netherlands. *Drink. Water Eng. Sci.*, 2: 1–14.

Sorour, M.H. and Shaalan, H.F. (2013). Removal of malathion using ceramic nanofiltration/adsorption system. *Desalin. Water Treat.*, 51(25–27): 5009–5013.

Speth, T.F. and Adams, J.Q. (1993). GAC and air stripping design support for the Safe Drinking Water Act. In: Clark, R. and S. Summers, (eds.), *Strategies and Technologies for Meeting SDWA Requirements*. Lewis Publishers, Ann Arbor, MI, pp. 47–89.

Speth, T.F. and Miltner, R.J. (1998). Technical note: adsorption capacity of GAC for synthetic organics. *J. Am. Water Works Assoc.*, 90(4): 171–174.

Starling, A.P., Umbach, D.M., Kamel, F., Long, S., Sandler, D.P. and Hoppin, J.A. (2014). Pesticide use and incident diabetes among wives of farmers in the Agricultural Health Study. *Occup. Environ. Med.*, 71(9): 629–635.

Summers, R.S., Knappe, D.R.U. and Snoeyink, V.L. (2010). Chapter 14: Adsorption of organic compounds by activated carbon. In: Edzwald, J.K. (ed.), *Water quality and treatment: A handbook on drinking water*. 6th edition. McGraw-Hill, New York, NY.

Titenko-Holland, N., Windham, G., Kolachana, P., Reinisch, F., Parvatham, S., Osorio, A.M. and Smith, M.T. (1997). Genotoxicity of malathion in human lymphocytes assessed using the micronucleus assay in vitro and in vivo: A study of malathion-exposed workers. *Mutat. Res.*, 388(1): 85–95.

Traul, K.A. (1987). Evaluation of CL 6601 in the bacterial/microsome mutagenicity test. Study no. 114 by American Cyanamid Company. Unpublished report, Cheminova A/S, CHA Doc. No.: 15 FYF. (as cited in WHO, 2017a)

USDA (2020). The Pesticide Data Program: PDP Database search. Agricultural Marketing Service, United States Department of Agriculture. Available at <https://apps.ams.usda.gov/pdp>.



U.S. EPA (1977). Evaluation of selected pesticides as chemical mutagens in vitro and in vivo studies. United States Environmental Protection Agency, EPA-600/1-77-028, Research Triangle Park, NC.

U.S. EPA (1997). Malathion: 2-year chronic feeding/carcinogenicity study in Fischer 344 rats. Huntingdon Life Sciences. 1996. MRID 43942901. Washington, D.C: Office of Pesticides and Toxic Substances, United States Environmental Protection Agency. Available at <https://archive.epa.gov/pesticides/chemicalsearch/chemical/foia/web/pdf/057701/057701-114.pdf>

U.S. EPA (1998). EPA Method 8270D Semivolatile organic compounds by gas chromatography/mass spectrometry (GC/MS). Rev. 4.

U.S. EPA (2000a). Final cancer assessment document, evaluation of the carcinogenic potential of malathion. United States Environmental Protection Agency, Cancer Assessment Review Committee, Health Effects Division, Office of Pesticide Programs, MRID 43975201, Tox review 013991.

U.S. EPA (2000b). EPA Method 8141B Organophosphorus compounds by gas chromatography. Rev 2.0.

U.S. EPA (2005). EPA Method 527 Determination of selected pesticides and flame retardants in drinking water by solid phase extraction and capillary column gas chromatography/mass spectrometry (GC/MS). Rev 1.0.

U.S. EPA (2007). EPA Method 1699: Pesticides in water, soil, sediment, biosolids, and tissue by HRGC/HRMS.

U.S. EPA (2009). Reregistration eligibility decision (RED) for malathion. United States Environmental Protection Agency, Office of Pesticide Programs, EPA 738-R-06-030, Washington, D.C.

U.S. EPA (2011). Finalization of guidance on incorporation of water treatment effects on pesticide removal and transformation in drinking water exposure assessments.

U.S. EPA (2016). Evaluation of carbaryl and malathion human studies for their proposed application in a physiologically based pharmacokinetic model for risk assessment. United States Environmental Protection Agency, Office of Pesticide Programs.

U.S. EPA (2018). 2018 edition of the drinking water standards and health advisories tables. United States Environmental Protection Agency, Office of Water, EPA 822-F-18-001, Washington, D.C. Available at <https://www.epa.gov/system/files/documents/2022-01/dwtable2018.pdf>

USGS (1983a). Method O-1104 - Methods for the determination of organic substances in water and fluvial sediments, Techniques of water-resources investigations of the United States geological survey, Book 5, Chapter A3. Edited by Wershaw, R.L., Fishman, M.J., Grabbe, R.R. and Lowe L.E.

USGS (1983b). Method O-3104 - Methods for the determination of organic substances in water and fluvial sediments, Techniques of water-resources investigations of the United States geological survey, Book 5, Chapter A3. Edited by Wershaw, R.L., Fishman, M.J., Grabbe, R.R. and Lowe L.E.

USGS (1995). Method O-1126-95 - Determination of pesticides in water by C-18 solid-phase extraction and capillary-column gas chromatography/mass spectrometry with selected-ion monitoring. United States Geological Survey, National Water Quality Laboratory.

USGS (2001). Method O-1402-01 - Determination of organophosphate pesticides in filtered water by gas chromatography with flame photometric detection. United States Geological Survey, National Water Quality Laboratory.

USGS (2003). Method O-3402-03 - Determination of organophosphate pesticides in whole water by continuous liquid-liquid extraction and capillary-column gas chromatography with flame photometric detection. United States Geological Survey, National Water Quality Laboratory.

- Valentine, R. L. and Jafvert, C. T. (1992). Reaction scheme for the chlorination of ammoniacal water. *Environ Sci. Technol.*, 26 (3): 577–86.
- van der Aa, L.T.J., Kolpa, R.J., Rietveld, L.C. and van Dijk, J.C. (2012). Improved removal of pesticides in biological granular activated carbon filters by pre-oxidation of natural organic matter. *J. Water Supply Res. Technol. AQUA*, 61(3): 153–163.
- Van der Bruggen, B. and Vandecasteele, C. (2003). Removal of pollutants from surface water and groundwater by nanofiltration: overview of possible applications in drinking water industry. *Environ Pollut*, 122: 435–445.
- Waddell, B.L., Zahm, S.H., Baris, D., Weisenburger, D.D., Holmes, F., Burmeister, L.F., Cantor, K.P. and Blair, A. (2001). Agricultural use of organophosphate pesticides and the risk of non-Hodgkin's lymphoma among male farmers (United States). *Cancer Causes Control*, 12(6): 509–517.
- WHO (2004). Malathion in drinking-water. Background document for development of WHO guidelines for drinking-water quality. World Health Organization, Geneva, Switzerland. Available at https://cdn.who.int/media/docs/default-source/wash-documents/wash-chemicals/malathion.pdf?sfvrsn=6a1d3db7_4
- WHO (2012). Water safety planning for small community water supplies. World Health Organization, Geneva, Switzerland. Available at <https://www.who.int/publications/i/item/9789241548427>
- WHO (2017a). Pesticide residues in food – 2016: toxicological evaluations/Special session of the Joint Meeting of the FAO Panel of Experts on Pesticide Residues in Food and the Environment and the WHO Core Assessment Group on Pesticide Residues, Geneva, Switzerland, 9–13 May, 2016.
- WHO (2017b). Guidelines for drinking-water quality. 4th edition incorporating the first addendum. World Health Organization, Geneva, Switzerland. Available at https://www.who.int/water_sanitation_health/publications/drinking-water-quality-guidelines-4-including-1st-addendum/en/
- Windham, G.C., Titenko-Holland, N., Osorio, A.M., Gettner, S., Reinisch, F., Haas, R. and Smith, M. (1998). Genetic monitoring of malathion-exposed agricultural workers. *American journal of industrial medicine. Am. J. Ind. Med.*, 33(2): 164–174.
- Wolfe, N.L., Zepp, R.G., Gordon, J.A., Baughman, G.L. and Cline, D.M. (1977). Kinetics of chemical degradation of malathion in water. *Environmental science and technology. Environ. Sci. Technol.*, 11(1): 88–93.
- Woudneh, B.M., Ou, Z., Sekela, M., Tuominen, T. and Gledhill, M. (2009a). Pesticides multiresidues in waters of the lower Fraser Valley, British Columbia, Canada. Part I. Surface Water. *J. Environ. Qual.*, 38: 940–947.
- Woudneh, B.M., Ou, Z., Sekela, M., Tuominen, T. and Gledhill, M. (2009b). Pesticides multiresidues in waters of the lower Fraser Valley, British Columbia, Canada. Part II. Groundwater. *J. Environ. Qual.*, 38: 948–954.
- Wu, C. and Linden, K.G. (2008). Degradation and byproduct formation of parathion in aqueous solutions by UV and UV/H₂O₂ treatment. *Water Res.*, 42(19): 4780–4790.
- Yokota, K., Fukuda, M., Katafuchi, R. and Okamoto, T. (2017). Nephrotic syndrome and acute kidney injury induced by malathion toxicity. *BMJ Case Rep.*, 2017: bcr2017220733.
- Yukon Environmental Health Services (2019). Personal communication with P. Brooks.
- Zhang, Y. and Pagilla, K. (2010). Treatment of malathion pesticide wastewater with nanofiltration and photo-Fenton oxidation. *Desalination*, 263(1–3): 36–44.



APPENDIX A: LIST OF ABBREVIATIONS

ACHe	acetylcholine esterase
ADI	acceptable daily intake
AHS	Agricultural Health Study
ANSI	American National Standards Institute
AOP	advanced oxidation processes
B6C3F1	mouse strain
bw	body weight
CAS	Chemical Abstracts Service
ChE	cholinesterase
CSA	CSA Group or Canadian Standards Association
DCA	dicarboxylic acid
DNA	deoxyribonucleic acid
F344/Fischer 344	rat strain
GAC	granular activated carbon
GD	gestational day
HBV	health-based value
HPRT assay	hypoxanthine phosphoribosyl transferase assay
IARC	International Agency for Research on Cancer
LOD	limit of detection
MAC	maximum acceptable concentration
MCA	monocarboxylic acid
MDL	method detection limit
MRL	method reporting limit
MWCO	molecular weight cut-off
NF	nanofiltration
NHL	non-Hodgkin lymphoma
NOAEL	no-observed-adverse-effect level
NOM	natural organic matter

NSF	NSF International
NTU	nephelometric turbidity unit
PAC	powdered activated carbon
PMRA	Pest Management Regulatory Agency
PND	postnatal day
RO	reverse osmosis
SCC	Standards Council of Canada
Sprague-Dawley	rat strain
TAF	toxicity adjustment factor
US	United States
U.S. EPA	United States Environmental Protection Agency
UV	Ultraviolet
WHO	World Health Organization



APPENDIX B: CANADIAN WATER QUALITY DATA

TABLE B1: Levels of malathion in Canadian aquatic sources and air from the National Water Quality Surveillance Program (2003–2005)

Jurisdiction (Year Sampled)	No. Detects/ Samples	MDL (ng/L)	Range (ng/L)	
			Min	Max
AB, SK, MB – 8 sites (2003)	0/13	14.7	Not available	Not available
AB, SK, MB – 15 sites (2003–2004)	0/30	14.70	< 14.70	< 14.70
BC – Lower Fraser Valley and Okanagan Basin (2003–2005)	7/96	0.062	< 0.062	75.1
ON (2003)	1/162	14.7	143	143
ON (2004)	2/228	14.7	31.7	449
ON (2005)	3/160	14.7	10.4	611
ON – 10 isolated lakes (2003–2005)	3/163	0.001	< 0.001	2.20
ON – 4 sites (2004–2005)	0/12	0.000	< 0.000	Not available
QC (2003)	0/49	20	Not available	Not available
QC (2004)	0/69	4–20	Not available	Not available
QC (2005)	0/62	20	Not available	Not available

MDL: method detection limit.

Note: Adapted from Environment Canada, 2011.